

STATE OF OREGON WATER SUPPLY WELL REPORT

WESTERBERG DRILLING INC. PO BOX 1228 MOLALLA, OR 97038

WELL I.D. LABEL# 151653 START CARD # 1072314 ORIGINAL LOG #

(as required by ORS 537.545 & 537.765 and OAR 690-205-0210)

(1) LAND OWNER Owner Well I.D. First Name Zahary Last Name Reutov

Company Address 28668 S Elisha Rd City Canby State OR Zip 97013

(2) TYPE OF WORK [X] New Well [ ] Deepening [ ] Conversion [ ] Alteration [ ] Abandonment

(2a) PRE-ALTERATION Casing: Dia + From To Gauge Stl Plstc Wld Thrd Seal: Material From To Amt sacks/lbs

(3) DRILL METHOD [X] Rotary Air [ ] Rotary Mud [X] Cable [ ] Auger [ ] Cable Mud [ ] Reverse Rotary [ ] Other

(4) PROPOSED USE [ ] Domestic [X] Irrigation [ ] Community [ ] Industrial/ Commercial [ ] Livestock [ ] Dewatering [ ] Thermal [ ] Injection [ ] Other

(5) BORE HOLE CONSTRUCTION Special Standard [ ] (Attach copy) Depth of Completed Well 314 ft.

Table with columns: Dia, From, To, Material, SEAL, Amt, sacks/lbs. Rows for Bentonite and Cement.

How was seal placed: Method [ ] A [ ] B [X] C [ ] D [ ] E [X] Other bent pled dry hydr Backfill placed from 314 ft. to 318 ft. Material silica sand Filter pack from 148 ft. to 318 ft. Material CSS Size 6/9 Seal Placement Begin Date 3-21-24 Begin Time 11:45

(5a) ABANDONMENT USING UNHYDRATED BENTONITE Proposed Amount P Actual Amount P

(6) CASING/LINER Casing Liner Dia + From To Gauge Stl Plstc Wld Thrd Shoe [ ] Inside [X] Outside [ ] Other Location of shoe(s) 318 Temp casing [X] Yes Dia 12 From +1 To 50.5

(7) PERFORATIONS/SCREENS Perforations Method Screens Type v wire Material SS Perf/ Casing/ Screen Screen Liner Dia From To width length # of slots Tel/ pipe size

(8) WELL TESTS: Minimum testing time is 1 hour [X] Pump [ ] Bailer [ ] Air [ ] Flowing Artesian Yield gal/min Drawdown Drill stem/Pump depth Duration (hr)

(9) LOCATION OF WELL (legal description) County CLACKAM Twp 4 S N/S Range 1 E E/W WM Sec 25 NE 1/4 of the SW 1/4 Tax Lot 1202 Tax Map Number Lot

Lat Long Street address of well Nearest address same

(10) STATIC WATER LEVEL Date SWL(psi) SWL(ft) Existing Well / Pre-Alteration Completed Well 4-3-24

Table with columns: SWL Date, From, To, Est Flow, SWL(psi), SWL(ft). Rows for dates 1-23-24 to 1-26-24.

(11) WELL LOG Ground Elevation Material From To soil & gravel 0 1 silt & clay brown 1 19 clay brown with gravel 19 28 cemented gravel 28 63 clay brown with packed sand brown 63 66 gravel 66 81 siltstone brown hard 81 87 gravel large 87 95 gravel & silt brown 95 100 cemented gravel with packed silt 100 127 packed silt brown hard 127 129 clay grey sticky 129 134 cemented sand brown with gravel 134 144 claystone grey 144 155 sand grey 155 158 siltstone grey green 158 162 sand grey 162 174 clay grey & brown 174 182 small gravel 182 184 Construction Begin Date 1-19-24 Begin Time 13:00 End Date 4-3-24

(unbonded) Water Well Constructor Certification I certify that the work I performed on the construction, deepening, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. License Number 1358 Date 4-17-24

(bonded) Water Well Constructor Certification I accept responsibility for the construction, deepening, alteration, or abandonment work performed on this well during the construction dates reported above. License Number 698 Date 4-17-24

**WATER SUPPLY WELL REPORT -**  
continuation page

**CLAC 78626**  
**WESTERBERG DRILLING INC.**  
**PO BOX 1228**

**WELL I.D. LABEL#** 51653  
**START CARD #** 1072314  
**ORIGINAL LOG #** [ ]

**(2a) PRE-ALTERATION**

**MOLALLA, OR 97148 Concerns**

Dia	+	From	To	Gauge	Stl	Plstc	Wld	Thrd
Material		From	To	Amt sacks/lbs				

**(5) BORE HOLE CONSTRUCTION**

BORE HOLE			SEAL		Amt	sacks/ lbs
Dia	From	To	Material	To		
					Calculated	
					Calculated	
					Calculated	
					Calculated	
					Calculated	

**FILTER PACK**

From	To	Material	Size

**(6) CASING/LINER**

Casing	Liner	Dia	+	From	To	Gauge	Stl	Plstc	Wld	Thrd

**(7) PERFORATIONS/SCREENS**

Perf/ Screen	Casing/ Liner	Screen Dia	From	To	Scrm/slot width	Slot length	# of slots	Tele/ pipe size

**(8) WELL TESTS: Minimum testing time is 1 hour**

Yield gal/min	Drawdown	Drill stem/Pump depth	Duration (hr)

From	To	Description	Amount	Units

**(10) STATIC WATER LEVEL**

SWL Date	From	To	Est Flow	SWL (psi)	+ SWL (ft)

Received  
APR 22 2024  
OWRD

**(11) WELL LOG**

Material	From	To
clay with gravel	184	190
sand grey with little gravel	190	198
packed silt with wood	198	205
siltstone grey	205	218
packed silt & sand grey	218	232
packed sand grey	232	236
siltstone brown green	236	249
sand loose & cemented grey coarse	249	265
siltstone grey	265	268
sand loose & packed black	268	280
siltstone grey & brown	280	289
clay blue	289	291
siltstone grey & green	291	298
packed sand green	298	304
sand grey coarse	304	312
silt grey & green	312	318

Name of person(s) who assisted with construction and Trainee License # / Helper #

Assistant Name	Type	#
Cody Stephenson	asst	

**Comments/Remarks**

5"x6" concentric reducer on top of 5" screen @ 187 ft  
This well was installed for groundwater permit G-18518  
We cut off the drive shoe at 318' before installing the screen to facilitate pulling back the casing to expose the screen.