

STATE OF OREGON  
WATER SUPPLY WELL REPORT

WESTERBERG DRILLING INC.  
PO BOX 1228  
MOLALLA, OR 97038

WELL I.D. LABEL# I	151664
START CARD #	1072785
ORIGINAL LOG #	CLACKAMAS 2041

(as required by ORS 537.545 & 537.765 and OAR 690-205-0210)

(1) LAND OWNER Owner Well I.D. \_\_\_\_\_  
 First Name \_\_\_\_\_ Last Name \_\_\_\_\_  
 Company Willamette Egg Farm  
 Address 31348 S. Highway 170  
 City Canby State OR Zip 97013

(2) TYPE OF WORK  New Well  Deepening  Conversion  
 Alteration (complete 2a & 10)  Abandonment (complete 5a)

(2a) PRE-ALTERATION  
 Dia + From To Gauge Std Plstc Wld Thrd  
 Casing: 12 0 486      
 Seal: Original

(3) DRILL METHOD  
 Rotary Air  Rotary Mud  Cable  Auger  Cable Mud  
 Reverse Rotary  Other Pump Hoist

(4) PROPOSED USE  Domestic  Irrigation  Community  
 Industrial/ Commercial  Livestock  Dewatering  
 Thermal  Injection  Other

(5) BORE HOLE CONSTRUCTION Special Standard  (Attach copy)  
 Depth of Completed Well 538 ft.

BORE HOLE				SEAL			
Dia	From	To	Material	From	To	Amt	sacks/lbs
						Calculated	
						Calculated	

How was seal placed: Method  A  B  C  D  E  
 Other \_\_\_\_\_  
 Backfill placed from \_\_\_\_\_ ft to \_\_\_\_\_ ft Material \_\_\_\_\_  
 Filter pack from \_\_\_\_\_ ft to \_\_\_\_\_ ft Material \_\_\_\_\_ Size \_\_\_\_\_  
 Seal Placement Begin Date \_\_\_\_\_ Begin Time \_\_\_\_\_

(5a) ABANDONMENT USING UNHYDRATED BENTONITE  
 Proposed Amount \_\_\_\_\_ Pounds Actual Amount \_\_\_\_\_ Pounds

(6) CASING/LINER

Casing	Liner	Dia	+	From	To	Gauge	Std	Plstc	Wld	Thrd
<input checked="" type="checkbox"/>	<input type="checkbox"/>	12	<input checked="" type="checkbox"/>	1.5	446	.250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	12	<input type="checkbox"/>	446	486	.375	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	10	<input type="checkbox"/>	483	538		<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Shoe  Inside  Outside  Other Location of shoe(s) \_\_\_\_\_  
 Temp casing  Yes Dia \_\_\_\_\_ From + \_\_\_\_\_ To \_\_\_\_\_

(7) PERFORATIONS/SCREENS  
 Perforations Method 12" Mills Knife/10" Torched  
 Screens Type \_\_\_\_\_ Material \_\_\_\_\_

Perf/S	Casing/Screen	Dia	From	To	Scrns/slot width	length	# of slots	Tele/pipe size
Perf	Casing	12	114	118		3	48	
Perf	Casing	12	189	192		3	32	
Perf	Casing	12	218	222		3	40	
Perf	Casing	12	269	273		3	40	
Perf	Liner	10	486	536		6	260	

(8) WELL TESTS: Minimum testing time is 1 hour  
 Pump  Bailer  Air  Flowing Artesian

Yield gal/min	Drawdown	Drill stem/Pump depth	Duration (hr)
425	76		4

Temperature 54 °F Lab analysis  Yes By \_\_\_\_\_  
 Water quality concerns?  Yes (describe below) TDS amount 173 ppm  
 From \_\_\_\_\_ To \_\_\_\_\_ Description \_\_\_\_\_ Amount \_\_\_\_\_ Units \_\_\_\_\_

(9) LOCATION OF WELL (legal description)  
 County CLACKAMAS Twp 5 S N/S Range 1 E E/W WM  
 Sec 9 SE 1/4 of the NE 1/4 Tax Lot 300  
 Tax Map Number \_\_\_\_\_ Lot \_\_\_\_\_  
 Lat \_\_\_\_\_ or 45.15356 DMS or DD  
 Long \_\_\_\_\_ or -122.68171 DMS or DD  
 Street address of well  Nearest address  
31348 S. Highway 170, Canby, OR 97013

(10) STATIC WATER LEVEL  

Existing Well / Pre-Alteration	Date	SWL(psi)	+ SWL(ft)
Completed Well	02-13-2024		76
	02-20-2024		76

 Flowing Artesian?  Dry Hole?

WATER BEARING ZONES Depth water was first found \_\_\_\_\_

SWL Date	From	To	Est Flow	SWL(psi)	+ SWL(ft)

(11) WELL LOG  
 Ground Elevation \_\_\_\_\_  
 Material From To  
 We performed mechanical and air redevelopment of this well as routine maintenance and at that time we raised the well casing from 0' to 1.5' above ground level.  
 No other alterations were performed at this time.  
 Received  
 MAY 06 2024  
 OWRD

Construction Begin Date 02-13-2024 Begin Time 08 00 End Date 02-20-2024

(unboxed) Water Well Constructor Certification  
 I certify that the work I performed on the construction, deepening, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief.

License Number \_\_\_\_\_ Date \_\_\_\_\_  
 Signed Daniel D. Stewart

(boxed) Water Well Constructor Certification  
 I accept responsibility for the construction, deepening, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief.

License Number 1487 Date 04-29-2024  
 Signed \_\_\_\_\_  
 Contact Info (optional) \_\_\_\_\_