

WATER WELL REPORT

STATE OF OREGON

08054

Pen: MDC
Type of well: Reconditioning
w/ah - reconditioning
Sec. 12 - 5/3/82
Caw

RECEIVED

APR 11 1982

WATER RESOURCES DEPT

State Well No.

35/1W-12da

State Permit No.

Reconditioning

(1) OWNER:

Name Oscar G. Williams, Sr.

Address 7115 S.W. Frogpond Ln.

City Wilsonville State Oregon

(2) TYPE OF WORK (check):

New Well ☐ Deepening ☐ Reconditioning ☒ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air ☒ Driven ☐ Domestic ☒ Industrial ☐ Municipal ☐
 Rotary Mud ☐ Dug ☐ Irrigation ☐ Test Well ☐ Other ☐
☐ Bored ☐ Thermal: Withdrawal ☐ Reinjection ☐

(4) PROPOSED USE (check):

(5) CASING INSTALLED:

Steel ☐ Plastic ☒
Threaded ☐ Welded ☐

" Diam. from ft. to ft. Gauge

" Diam. from ft. to ft. Gauge

LINER INSTALLED:

4 1/2" Diam. from 0 ft. to 200 ft. Gauge Sch. 40

(6) PERFORATIONS:

Perforated ☒ Yes ☐ No

Type of perforator used Saw

Size of perforations 180 in. by 6 in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☐ No

Manufacturer's Name

Type Model No.

Diam. Slot Size Set from ft. to ft.

Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☐ No If yes, by whom?

gal./min. with ft. drawdown after hrs.

Air test gal./min. with drill stem at ft. hrs.

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes ☐ No ☐

Well seal—Material used Cement

Well sealed from land surface to 37 ft. ft.

Diameter of well bore to bottom of seal 105/8 in. ft.

Diameter of well bore below seal 6 in.

Number of sacks of cement used in well seal 13.5 sacks

How was cement grout placed? pumped from bottom to top.

Was pump installed? Type HP Depth ft.

Was a drive shoe used? ☐ Yes ☐ No Plugs Size: location ft.Did any strata contain unusable water? ☐ Yes ☐ No

Type of Water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☐ No Size of gravel: ft.

Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Clackamas

Driller's well number

D-354 81(A)

N.E. 1/4 S.E. 1/4 Section

T. 3S

R. 1W

W.M.

Tax Lot #

Lot

Blk

Subdivision

Address at well location: Same

(11) WATER LEVEL: Completed well.

Depth at which water was first found ft.

Static level 74

ft. below land surface. Date 3/31/82

Artesian pressure

lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6

Depth drilled

ft. Depth of completed well 199 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Original well was drilled by driller Bruce Eberly #1355	4/17/81		
(Surface seal repair)			
Surface seal was drilled by 105/8 O.D. Wash over pipe to depth of approx 37 ft. See construction (9).			
Checked depth of well, depth was 199 ft.			
Typing error on original log on liner pipe.			
See casing installed (5), should read 0-200 ft Linner pipe			
Perforation (6) is right on original log.			

Work started March 30 1982 Completed March 31 1982

Date well drilling machine moved off of well -- March 31 1982

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Walter Mace Date 4/1, 1982.
(Drilling Machine Operator)

Drilling Machine Operator's License No. 595

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name S & M DRILLING & SUPPLY, INC.

(Person, firm or corporation)

(Type or print)

Address 399 S.E. Walnut, Canby, Oregon

[Signed] Walter Mace
(Water Well Contractor)

Contractor's License No. 497 Date 4/1, 1982

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,

SALEM, OREGON 97310

within 30 days from the date of well completion.

SP*12658-690

CLAC

State Permit No.

GP#12658-690