

CLAC 08148

RECEIVED NOV 3 1966 Well #2

WATER WELL REPORT ENGINEER

3/1w-14 B

NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE OF OREGON (Please type or print) G-4669

State Permit No.

(1) OWNER: Name Walnut Park Trailer Park Address Wilsonville, Oregon

(2) LOCATION OF WELL: County Clackamas Driller's well number 1/4 Section 14 T. 3S R. 1W W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check): Well [x] Deepening [] Reconditioning [] Abandon [] Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check): Domestic [x] Industrial [] Municipal [] Irrigation [] Test Well [] Other [] (5) TYPE OF WELL: Rotary [] Driven [] Cable [x] Jetted [] Dug [] Bored []

(6) CASING INSTALLED: Threaded [] Welded [x] 6" Diam. from 0 ft. to 140 ft. Gage 1/4" 5 1/2" Diam. from 135 ft. to 155 ft. Gage 1/4"

(7) PERFORATIONS: Perforated? [x] Yes [] No Type of perforator used torch (liner perforated) Size of perforations 1/8 in. by 8 in. 160 perforations from 140 ft. to 154 ft.

(8) SCREENS: Well screen installed? [] Yes [x] No Manufacturer's Name Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION: Well seal—Material used in seal Puddled Mud Depth of seal 30 ft. Was a packer used? no Diameter of well bore to bottom of seal 10 in. Were any loose strata cemented off? [] Yes [x] No Depth Was a drive shoe used? [] Yes [x] No Was well gravel packed? [] Yes [x] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusuable water? [] Yes [x] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS: Static level 60 ft. below land surface Date 10/18/66 Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? [x] Yes [] No If yes, by whom? driller Yield: 15 gal./min. with 60 ft. drawdown after 8 hrs.

Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [] Yes [x] No

(12) WELL LOG: Diameter of well below casing 6 Depth drilled 155 ft. Depth of completed well 155 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include Soil (0-3), Brown sandy clay (3-21), Clay and boulders (21-38), Yellow clay (38-54), Blue clay (54-61), Yellow clay Broken rock (61-94), Red clay Broken rock (94-103), Brown sandy clay (103-116), Dark brown clay (116-121), Broken rock and clay (121-155).

Work started October 7 19 66 Completed October 18 19 66 Date well drilling machine moved off of well October 18 19 66

(13) PUMP: Manufacturer's Name Type: H.P.

Water Well Contractor's Certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME John Truman Miller (Person, firm or corporation) Address P O Box 42 Hubbard, Oregon Drilling Machine Operator's License No. 26 [Signed] John T. Miller (Water Well Contractor) Contractor's License No. 277 Date October 22 19 66