

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

**RECEIVED**  
 CLAC  
 WATER WELL REPORT well #3  
 JUN 17 1968  
 STATE OF OREGON  
 STATE ENGINEER  
 SALEM, OREGON  
 G-4669

CLAC  
 08149  
 State Well No. 3/1w-14 B  
 State Permit No.

**(1) OWNER:**

Name Walnut Park Mobile Ranch  
 Address Rt 2 Box 68C, Ulsanville, Ore

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
 If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Driven   
 Cable  Jetted   
 Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
 Irrigation  Test Well  Other

**CASING INSTALLED:**

Threaded  Welded   
 6" Diam. from 0 ft. to 2.48 ft. Gage 1.25  
 " Diam. from ft. to ft. Gage  
 " Diam. from ft. to ft. Gage

**PERFORATIONS:**

Perforated?  Yes  No.

Type of perforator used

Size of perforations in. by in.  
 perforations from ft. to ft.  
 perforations from ft. to ft.  
 perforations from ft. to ft.  
 perforations from ft. to ft.  
 perforations from ft. to ft.

**(7) SCREENS:**

Well screen installed?  Yes  No

Manufacturer's Name  
 Type Model No.  
 Diam. Slot size Set from ft. to ft.  
 Diam. Slot size Set from ft. to ft.

**(8) WATER LEVEL: Completed well.**

Static level 34 ft. below land surface Date 6-8-68  
 Artesian pressure lbs. per square inch Date

**(9) WELL TESTS:**

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom? Driller  
 100 gal./min. with 272 ft. drawdown after 2 hrs.  
 80 " 112 " 1 "  
 60 " 92 " 1 "

Baller test gal./min. with ft. drawdown after hrs.  
 Artesian flow g.p.m. Date

Temperature of water 52 Was a chemical analysis made?  Yes  No

**(10) CONSTRUCTION:**

Well seal—Material used Bentonite  
 Depth of seal 28 ft.  
 Diameter of well bore to bottom of seal 10 in.  
 Were any loose strata cemented off?  Yes  No Depth  
 Was a drive shoe used?  Yes  No  
 Did any strata contain unusable water?  Yes  No  
 Type of water? depth of strata  
 Method of sealing strata off  
 Was well gravel packed?  Yes  No Size of gravel:  
 Gravel placed from ft. to ft.

**(11) LOCATION OF WELL:**

County Clackamas Driller's well number  
 1/4 Section 14 T. 35 R. 1 W. W.M.  
 Bearing and distance from section or subdivision corner

**(12) WELL LOG:**

Diameter of well below casing 6

Depth drilled 306 ft. Depth of completed well 306 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Topsoil	0	3	
Clay brown	3	14	
Gravel & small boulders	14	28	
Clay brown	28	32	
Clay grey	32	45	
Clay blue	45	130	
Clay brown	130	143	
Clay grey sandy	143	159	
Clay grey	159	234	
Basalt decomposed water 15 gpm	234	264	37
Basalt hard	264	268	
Basalt 20 gpm	268	284	37
Basalt decomposed 40 gpm	284	298	
Basalt hard	298	302	
Basalt broken 100 gpm	302	306	34

Work started 4-29 1968 Completed 5-7 1968

Date well drilling machine moved off of well 5-8 1968

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Maxwell Skyles Date May 5, 1968  
 (Drilling Machine Operator)

Drilling Machine Operator's License No. 224

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Skyles Drilling & Supply  
 (Person, firm or corporation) (Type or print)

Address Cladstone, Oregon

[Signed] George A. Skyles  
 (Water Well Contractor)

Contractor's License No. 58 Date May 8, 1968