

NOTICE TO WATER WELL CONTRACTOR

The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

STATE ENGINEER

State Well No. 35/1w-16

State Permit No.

(1) OWNER:

Name

Address

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED:

Threaded ☐ Welded ☐

8" Diam. from 18 ft. to 155 ft. Gage 4
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? ☒ Yes ☐ No.

Type of perforator used

Size of perforations 3/8 in. by 8 in.
96 perforations from 95 ft. to 155 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

155 after 1 hr
300 g.p.m. from 110 ft. drawdown after 1 hrs.

Artesian flow g.p.m.
Temperature of water 55 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement

Well sealed from land surface to 65 ft.

Diameter of well bore to bottom of seal 9 3/8 in. sealed with neoprene seal

Diameter of well bore below seal 9 3/8 in.

Number of sacks of cement used in well seal 20 sacks

Number of sacks of bentonite used in well seal sacks

Brand name of bentonite

Number of pounds of bentonite per 100 gallons

of water lbs./100 gals.

Was a drive shoe used? ☐ Yes ☐ No Plugs Size: location ft.Did any strata contain unusable water? ☐ Yes ☐ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☐ No Size of gravel:

Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Clackamas Driller's well number

1/4 1/4 Section T. R. W.M.

Bearing and distance from section or subdivision corner

Sec 1 E T3S R12W

(11) WATER LEVEL: Completed well.

Depth at which water was first found 90 ft.

Static level 42 ft. below land surface. Date 5/29/74

Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing

Depth drilled 155 ft. Depth of completed well 155 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change in
position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	2	
Brown Clay	2	25	
red clay	25	50	
Soft rock	50	120	
Med. Grained Basalt	120	155	

Work started 5/29 1974 Completed 5/29/74

Date well drilling machine moved off of well 5/29 1974

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision.
Materials used and information reported above are true to my
best knowledge and belief.

[Signed] [Signature] Date 6/23, 1974

Drilling Machine Operator's License No. 82

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is
true to the best of my knowledge and belief.

Name [Signature] (Person, firm or corporation) (Type or print)

Address 729 N Main Street

[Signed] [Signature] (Water Well Contractor)

Contractor's License No. 117 Date 6/23, 1974