

RECEIVED
MAR 28 1967

CLAC
00842

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE ENGINEER
WATER WELL REPORT
STATE OF OREGON
(Please type or print)
G-3984
State Well No. 1/3-35P
State Permit No.

(1) OWNER:
Name Vic Thompson,
Address Rt 3 Box - 288
Aresham, Oreg.

(2) LOCATION OF WELL:
County Clackamas Driller's well number
1/4 1/4 Section 35 T. 15 R. 3E, W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other
(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:
Threaded Welded
" Diam. from " ft. to " ft. Gage
6 " Diam. from 3.38 ft. to 4.10 ft. Gage 2.50
" Diam. from " ft. to " ft. Gage

(7) PERFORATIONS:
Perforated? Yes No
Type of perforator used Torrid cut,
Size of perforations 1/4 in. by 10 in.
190 perforations from 350 ft. to 400 ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

(8) SCREENS:
Well screen installed? Yes No
Manufacturer's Name
Model No.
Diam. Slot size Set from " ft. to " ft.
Diam. Slot size Set from " ft. to " ft.

(9) CONSTRUCTION: deepening
Well seal—Material used in seal
Depth of seal " ft. Was a packer used?
Diameter of well bore to bottom of seal " in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: 1/2" minus
Gravel placed from 338 ft. to 410 ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 500 ft. below land surface Date March 67
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: 100 gal./min. with 60 ft. drawdown after 2 hrs.
" 125 " " 65 " " 2 "
" 150 " " 80 " " 2 "
Bailer test 20 gal./min. with 15 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water 53 Was a chemical analysis made? Yes No

(12) WELL LOG:
Diameter of well below casing 4 1/2 " bottom
Depth drilled 410 ft. Depth of completed well 410 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

| MATERIAL | FROM | TO |
|-----------------|------|-----|
| Well (origia) - | 345 | |
| blue clay | 345 | 358 |
| solid stone | 358 | 400 |
| clay & sand | 400 | 410 |

before deepening,
static table - 180'
drilled open hole
345' 410'
gravel packed liner in bottom
Work started March 1967 Completed March 1967
Date well drilling machine moved off of well March 1967

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME H.O. Olvey (Type or print)
Address 18211 SE Powell Aresham,
Drilling Machine Operator's License No. 314
[Signed] H.O. Olvey (Water Well Contractor)
Contractor's License No. 282 Date March 25, 1967