

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

STATE ENGINEER

CLAC

WATER WELL REPORT

08542

3/1W-25 D

STATE OF OREGON (Please type or print)

State Well No. _____

G-4524

State Permit No. _____

AUG 28 1962

(1) OWNER:

Name PAUL M BROWN
Address 2853 NW FAIRFAX TERRACE PORTLAND
located Rt 2, Aurora Ore

(2) LOCATION OF WELL:

County CLACKAMS Driller's well number
Bearing and distance from section or subdivision corner
550 FT. SOUTH, 200 FT. EAST from NW corner, sec. 25

(3) TYPE OF WORK (check):

Well [X] Deepening [] Reconditioning [] Abandon []

(4) PROPOSED USE (check):

Domestic [X] Industrial [] Municipal []
Irrigation [] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven []
Cable [X] Jetted []
Dug [] Bored []

(6) CASING INSTALLED:

12" Diam. from 0 ft. to 10 ft. Gage
10" Diam. from 0 ft. to 80 ft. Gage

(7) PERFORATIONS:

Type of perforator used mill knife
Size of perforations in. by in.
12 perforations from 54 ft. to ft.
12 perforations from 63 ft. to ft.
18 perforations from 71 ft. to ft.

(8) SCREENS:

Well screen installed [] Yes [] No
Manufacturer's Name _____ Model No. _____

(9) CONSTRUCTION:

Well seal—Material used in seal 10 ft. 12 in. pipe cem.
Depth of seal _____ ft. Was a packer used?
Diameter of well bore to bottom of seal _____ in.
Were any loose strata cemented off? [] Yes [] No Depth _____
Was a drive shoe used? [] Yes [] No
Was well gravel packed? [] Yes [] No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? [] Yes [] No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 22 ft. below land surface Date
Artesian pressure _____ lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level.
Was a pump test made? [X] Yes [] No If yes, by whom? J.T. Miller
Yield: 325 gal./min. with 43 ft. drawdown after 6 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 50 Was a chemical analysis made? [] Yes [] No

(12) WELL LOG:

Diameter of well below casing 10
Depth drilled 80 ft. Depth of completed well 80ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include surface, clay, yellow, clay, fine, sandy, yellow, coarse sand, red, clay, blue, coarse gravel, clay, brown, coarse sand and gravel, small sand and gravel, large gravel.

Work started 7-24-1962 Completed 8-2-1962
Date well drilling machine moved off of well 19

(13) PUMP:

Manufacturer's Name _____
Type: RAPIDAYTON H.P. 1

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J.T. Miller (Person, firm or corporation) (Type or print)
Address Box 175, Aurora, Ore.

Drilling Machine Operator's License No. Q, 191

[Signed] J.T. Miller (Water Well Contractor)
Contractor's License No. 7 Date 8-6-1962