WATER WELL REPORT
STATE OF OREGON

RECEIVED
AUG 20 1981
WATER RESOURCES DEPT
SALEM, OREGON

RECEIVED
AUG 12 1981
WATER RESOURCES DEPT
SALEM, OREGON

State Well No. 3S/1W-25

State Permit No. 08563

CLAC

(1) OWNER:
Name Steve Sander
Address 5318 S.W. Lakeview Blvd.
City Lake Oswego State OR.

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary Air ☑ Driven ☐
Rotary Mud ☐ Dug ☐
Cable ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐
Thermal: Withdrawal ☐ Reinjection ☐

CASING INSTALLED: Steel ☑ Plastic ☐ Threaded ☐ Welded ☑
6" Diam. from +1 ft. to 72 ft. Gauge 0.25 in.
" Diam. from ft. to ft. Gauge

LINER INSTALLED:
" Diam. from ft. to ft. Gauge

(6) PERFORATIONS: Perforated? ☐ Yes ☑ No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☑ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " "
Air test 30 gal./min. with drill stem at 68 ft. 1 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

CONSTRUCTION: Special standards: Yes ☐ No ☑
Well seal—Material used Cement - 5% Bentonite
Well sealed from land surface to 30 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 10 sacks
How was cement grout placed? pumped to bottom of annulus
Was pump installed? No Type HP Depth ft.
Was a drive shoe used? ☑ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☐ No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Clackamas Driller's well number
¼ ¼ Section 25 T. 3S R. 1W W.M.
Tax Lot # Lot Blk Subdivision
Address at well location:

(11) WATER LEVEL: Completed well.
Depth at which water was first found 52 ft.
Static level 38 ft. below land surface. Date 7-27-81
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing
Depth drilled 75 ft. Depth of completed well 72 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	3	
Brown Clay	3	52	
Black Sand	52	66	
Sand & gravel	66	75	

Work started 7-27 1981 Completed 7-27 1981
Date well drilling machine moved off of well 7-27 1981

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Daniel Donnell (Drilling Machine Operator) Date 7-29 1981
Drilling Machine Operator's License No. 883

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name AQUA-TECH Well Construction Inc. (Person, firm or corporation) (Type or print)
Address 2745 19th Ave. S.E. Salem
[Signed] David Beach (Water Well Contractor)
Contractor's License No. 696 Date 8/10 1981

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*12658-690