


STATE ENGINEER
Salem, Oregon



STATE WELL NO. 3/1W-25N
COUNTY CLACKAMAS
APPLICATION NO. GR-2499

CLAG

OWNER: Wayne W. Russell

MAILING ADDRESS: Rt. 2, Box 269

LOCATION OF WELL: Owner's No.

CITY AND STATE: Aurora, Oregon

SW 1/4 SW 1/4 Sec. 25 T. 5 S., R. 1 W., W.M.

Bearing and distance from section or subdivision corner 300' E. & 1250' N.

Section

Altitude at well

TYPE OF WELL: Drilled Date Constructed 1952

Depth drilled 127 Depth cased 127

CASING RECORD:

12-inch

FINISH:

Perforated

AQUIFERS:

WATER LEVEL:

36-feet

PUMPING EQUIPMENT: Type Jacuzzi Turbine

H.P. 15

Capacity 300 G.P.M.

WELL TESTS:

Drawdown 16+ ft. after _____ hours Pumping 500 G.P.M.

Drawdown _____ ft. after _____ hours _____ G.P.M.

USE OF WATER Irrigation Temp. _____ °F. _____, 19_____

SOURCE OF INFORMATION GR-2366

DRILLER or DIGGER J. T. Miller & Son, Aurora, Oregon

ADDITIONAL DATA:

Log _____ Water Level Measurements _____ Chemical Analysis _____ Aquifer Test _____

REMARKS:

STATE ENGINEER
Salem, Oregon

CLAC Well Record
08578

STATE WELL NO. 3/1W-25N(1)
COUNTY Clackamas
APPLICATION NO. _____

CLAC

OWNER: Wayne Russell

MAILING ADDRESS: _____
CITY AND STATE: _____

LOCATION OF WELL: Owner's No. _____

..... 1/4 1/4 Sec. T. N. E.
S., R. W., W.M.

Bearing and distance from section or subdivision corner _____

Altitude at well 150

TYPE OF WELL: Drilled Date Constructed 1952

Depth drilled 127 Depth cased 127

Section _____

CASING RECORD:

12 inch

FINISH:

Casing perforated

AQUIFERS:

Sand and gravel

WATER LEVEL:

40 feet below land surface on February 1, 1960

PUMPING EQUIPMENT: Type Turbine H.P. 15
Capacity _____ G.P.M.

WELL TESTS:

Drawdown _____ ft. after _____ hours _____ G.P.M.

Drawdown _____ ft. after _____ hours _____ G.P.M.

USE OF WATER Domestic, Irrigation (62 acres) Temp. _____ °F., 19_____

SOURCE OF INFORMATION USGS

DRILLER or DIGGER _____

ADDITIONAL DATA:

Log _____ Water Level Measurements _____ Chemical Analysis _____ Aquifer Test _____

REMARKS: