

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

CLAC 865

00865

WATER WELL REPORT

RECEIVED JUL 17 1967

State Well No. 1/3-36

STATE OF OREGON (Please type or print)

State Permit No.

(1) OWNER

Name Pacific Fur Food Inc.
Address Boring, Oreg.

(2) LOCATION OF WELL:

County Clackamas Driller's well number
1/4 Section 36 T. 1S R. 3E W.M.
Bearing and distance from section or subdivision corner

TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
In abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
8" Diam. from 0 ft. to 283 ft. Gage 247
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used Mills Knife
Size of perforations 3/16 in. by 3 in.
40 perforations from 200 ft. to 208 ft.
96 perforations from 220 ft. to 244 ft.
120 perforations from 250 ft. to 280 ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Cement Sand
Depth of seal below 90 ft. Was a packer used? Beckhill
Diameter of well bore to bottom of seal 12 with clay above 90'
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 70 ft. below land surface Date Feb-67
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: 125 gal./min. with 70 ft. drawdown after 2 hrs.
" 175 " " 105 " " 4 "
" " " " " " "
Bailer test 30 gal./min. with 10 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water 53 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 8"
Depth drilled 310 ft. Depth of completed well 310 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil	0	2
red clay	2	30
clay + gravel	30	40
black cemented gravel	40	75
cement gravel	75	173
clay + sand	173	182
cement gravel dry	182	200
cement water bearing	200	208
clay + gravel dry	208	220
water bearing cement	220	280
brown clay	280	285
gravel sand stone	285	306
blue clay	306	310

10" surface pipe set to 90"

Work started Jan 19 67 Completed Feb 19 67
Date well drilling machine moved off of well Feb 19 67

(13) PUMP:

Manufacturer's Name Western Lumber
Type: Line shaft turbine, H.P. 10

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME A.O. Olson (Person, firm or corporation) (Type or print)
Address 18211 S.E. Powell
Drilling Machine Operator's License No. 214
[Signed] A.O. Olson (Water Well Contractor)
Contractor's License No. 282 Date March, 19 67