NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED JAN 14 1970 STATE ENGINEER SALEM, OREGON

CLAC 08663

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

State Well No. 3/1W-28 bo
State Permit No.

(1) OWNER:
Name Orville Mulenburg
Address RT 4, Box 354 Sherwood, Ore

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED:
Threaded ☐ Welded ☒
[illegible]" Diam. from 0 ft. to 187 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:
Perforated? ☐ Yes ☒ No.
[illegible]e of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.
Static level 23 ft. below land surface Date 1-6-70
Artesian pressure lbs. per square inch Date

([illegible]) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☐ No If yes, by whom? Operator
Yield: 80 gal./min. with 237 ft. drawdown after 2 hrs.
" " " "
[illegible] " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 51° Was a chemical analysis made? ☐ Yes ☒ No

(10) CONSTRUCTION:
Well seal—Material used Cement Grout
Depth of seal 0 To 187 ft.
Diameter of well bore to bottom of seal 9 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☐ Yes ☒ No
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:
County Clackamas Driller's well number 155
SE ¼ NW ¼ Section 28 T. 3S R. 1W W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:
Diameter of well below casing 6"
Depth drilled 260 ft. Depth of completed well 260 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Brown Sandy Clay	0	62	
Coarse Gravel, Fine Sand	62	68	
Medium Fine Gray Sand	68	184	
Hard Gray Basalt	184	204	
Gray, Brown Broken Basalt	204	238	
Brown Porous Basalt (Water)	238	256	23
Hard Gray Basalt	256	260	

Work started 1-2 19 70 Completed 1-6 19 70
Date well drilling machine moved off of well 1-6 19 70

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Raymond A. Borchers Date 1-6, 19 70
(Drilling Machine Operator)
Drilling Machine Operator's License No. 305

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME B & S Drilling Co.
(Person, firm or corporation) (Type or print)
Address RT 3, Box 271A Sherwood
[Signed] Raymond A. Borchers
(Water Well Contractor)
Contractor's License No. 404 Date 1-6, 19

(USE ADDITIONAL SHEETS IF NECESSARY)