

RECEIVED

JUN 11 1968
STATE ENGINEER OF OREGON
SALEM OREGON

(Do not write above this line)

CLAC
08666
G-4513

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

State Well No. 3/1w-28 Q
State Permit No. _____

(1) OWNER:
Name Nathan J. Kurth
Address 8135 72nd Ave. NE (Rt. 6) Salem, Oregon

(2) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored
(4) PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:
10 " Diam. from top 120 ft. to 250 ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS: Perforated? Yes No.
Type of perforator used Mills
Size of perforations 2 in. by 3/8 in.
340 perforations from 80 ft. to 105 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(7) SCREENS: Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.
Static level 1 ft. below land surface Date 6-6-68
Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Driller
Yield: 300 gal./min. with 95 ft. drawdown after 8 hrs.
270 " " 80 " " 8 "
" " " " " "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 52 Was a chemical analysis made? Yes No

(10) CONSTRUCTION:
Well seal—Material used Drill cuttings puddle clay
Depth of seal _____ 20 ft.
Diameter of well bore to bottom of seal 14 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:
County Clackamas Driller's well number 1319
1/4 1/4 Section 28 T. 3S R. 1W W.M.
Bearing and distance from section or subdivision corner _____

(12) WELL LOG: Diameter of well below casing _____
Depth drilled 120 ft. Depth of completed well 120 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top Soil	0	2	
Yellow Clay	2	12	
Sandy Blue Clay	12	50	
Blue Clay	50	80	
Gravel	80	105	1
Blue Clay	105	120	

Work started 5-27-68 19 6-6-68 19
Completed 6-6-68 19
Date well drilling machine moved off of well 6-6-68 19

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Ronald Morton Date 6-6-68, 19
(Drilling Machine Operator)

Drilling Machine Operator's License No. 536

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING COMPANY
(Person, firm or corporation) (Type or print)
Address 7641 35th Ave. NE Salem, Oregon
[Signed] Emil D. Beier
(Water Well Contractor)

Contractor's License No. 2 Date 6-7-68, 19