The original and first contractor of this report are to be MAR 24 1970 STATE OF OREGON STATE ENGINEER, SALEM, OREGON 97310 Within 30 days from the STEATE ENGINEER SALEM. OREGON Within 30 days from the STEATE ENGINEER write above this line) of well completion. SALEM. OREGON

State Permit No.

(1) OWNER:	(11) LOCATION OF WELL:			
Name Harold Langdon	County Clackamas Driller's well number			
Address Rt.2, Box 272, Aurora, Oregon	14 14 Section 35 T. 3S R.1 W W.M			
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivision	on corner	· · · · ·	- ·
New Well Deepening Reconditioning Abandon	1			
If abandonment, describe material and procedure in Item 12.	· ·			
Rotary D Driven D	(12) WELL LOG: Diameter of well	helow cas	sing 6	I
Cable 🛽 Jetted 🗌 Domestic 🖫 Industrial 🗎 Municipal 🗆	Depth drilled 150 ft. Depth of comp			
Dug	Formation: Describe color, texture, grain size			
CASING INSTALLED: Threaded Weldedx Weldedx Cage tstd.	and show thickness and nature of each stratu with at least one entry for each change of forn in position of Static Water Level as drilling pr	ım and a nation. R	quifer p	enetrated
ft. toft. Gage	MATERIAL	From	то	SWL
	Top soil	0	1	5.7.2
PERFORATIONS: Perforated? T Ves 57 No.		1	5	
- originated: [res [res.	clay - brown - sandy clay "	5	40	.
	sand - brown-hard- dry			
Size of perforations in. by in.	dark- cemented	40	60	
perforations from ft. to ft.	sand - brown- clay	60	70	
perforations from ft. to ft.	clay - brown - sand hard	70	80	
perforations fromft. toft.	sand - brown- water, littl		-90	35
perforations fromft. toft.	sand-brown-clay - heaves			
perforations from ft. to ft.	pipe up	- 00	100	
(7) SCREENS: Well screen installed? Yes No	sand - clay - little water	r	100	35
Manufacturer's Name		100	110	
Type Model No.	sand- gray- clay	110	115	
Diam. Slot size Set from ft. to ft.	clay- gray	115	120	
Diam. Slot size Set from ft. to ft.	sand gray	120	123	
	sand- black- water	123	130	40
(8) WATER LEVEL: Completed well.	clay - gray - sand	130	140	
Static level 40 ft. below land surface Date 3/4/70	sand- gray	140	143	
sian pressure lbs. per square inch Date	sand- brown	143		
(9) WELL TESTS: Drawdown is amount water level is lowered below static level	gravel- little gray sand	146	150	
Was a pump test made? Yes No If yes, by whom? Owner	Work started Bab 26	35		
Yield: 40 gal./min. with 60 ft. drawdown after 2 hrs.	Work started Feb26 19 70 Complete		<u>'• 2</u>	19 70
" " " " " " " " " " " " " " " " " " " "	Date well drilling machine moved off of well	Mar.	7	19 70
70	Drilling Machine Operator's Certification:			
Bailer test 30 gal./min. with ft. drawdown after 2 hrs.	This well was constructed under my di rials used and information reported abov	rect supe	rvision.	Mate-
Artesian flow g.p.m. Date	knowledge and belief.	e are ar	ue to i	ny best
Temperature of water Was a chemical analysis made? ☐ Yes ☐ No	[Signed] (Drilling Machine Operator)	Date .ma	ar.23	79.70
(10) CONSTRUCTION:	- · · · · ·	210		
Well seal—Material used Betonite	Drilling Machine Operator's License No	219		
Depth of seal ft.	Water Well Contractor's Certification:			
Diameter of well bore to bottom of sealin.	This well was drilled under my jurisdiction and this report is			
Were any loose strata cemented off? Tyes I No Depth	arde to the best of my knowledge and belie	f.		A
Was a drive shoe used? ** Yes \[\bigcap \ No \]	NAMEBarron & Straver (Person, firm or corporation) (Type or 976005			
Did any strata contain unusable water? Yes No				
Type of water? depth of strata	Addres 7990 S.W. SorrentoRd. B	eaver	ton,	Jre
Method of sealing strata off	and and see			
Was well gravel packed? Yes No Size of gravel:	[Signed] (Water Well Contract	or)		***********
Gravel placed from ft. to ft.			70	
II. IO.	Contractor's License No. 25 Date	3/23/	<u> </u>	19