NOTICE TO WATER WELL CONTRACT The original and first copy VELL REPORT of this report are to be State Well No. 3//W-35 state engineer, salem, oregon 2310

STATE Engineer, salem, oregon 2310

Within 30 days from the date

ATE ENGINEER

SALEM. OF Well completion. OF OREGON 0 1970 (Figure type or print)
(Do not write above this line) SALEM OF (1) OWNER: (11) LOCATION-OF WELL: Name Jim Langden Clackamus Driller's well number AddressRte 2 Box 274 Aurora, Oregon 34 Section 35 T. 3S R. 1W W.M. Bearing and distance from section or subdivision corner (2) TYPE OF WORK (check): New Well 🔯 Deepening | Reconditioning [ Abandon [ If abandonment, describe material and procedure in Item 12. (3) TYPE OF WELL: (4) PROPOSED USE (check): (12) WELL LOG: Rotary 🔂 Driven 🗌 Diameter of well below casing ..... Cable Depth drilled 203 ft. Depth of completed well Irrigation 🖫 Test Well 🗌 Other Formation: Describe color, texture, grain size and structure of materials; CASING INSTALLED: Threaded Welded X 12 "Diam. from 0 ft. to 203 ft. Gage 14" CASING INSTALLED: and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates. \_\_\_\_\_\_ft. to \_\_\_\_\_\_ft. Gage \_\_\_\_\_ MATERIAL. Soil PERFORATIONS: Brown sandy Clay Perforated? Ty Yes | No. 124 Type of perforator used Torch Sand 124 146 Sand & gravel (red) 158 3/8 in. by 146 Size of perforations 8 Gravel & clay streaks 400 perforations from 147 ft. to 197 ft. 158 200 Blue sandy clay 200 203 ..... perforations from ...... ft. to ..... ft. perforations from ...... ft. to ..... perforations from ...... ft. to ..... perforations from \_\_\_\_\_ ft. to \_\_\_\_ (7) SCREENS: Well screen installed? ☐ Yes 🛛 No Manufacturer's Name Model No. Diam. Slot size ...... Set from ..... ft. to ..... Diam. ..... Slot size ..... Set from ..... ft. to ..... (8) WATER LEVEL: Completed well. Static level ft. below land surface Date 0/10/70 sian pressure lbs. per square inch Date (9) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? X Yes \( \backslash \) No If yes, by whom? Work started 5/11/70 Yield: 325 gal./min. with 100 ft. drawdown after 3 19 Completed 6/10 Date well drilling machine moved off of well 19 **Drilling Machine Operator's Certification:** This well was constructed under my direct supervision. Materials used and information reported above are true to my best Bailer test gal./min. with \_\_\_ft. drawdown after Artesian flow knowledge and bolief, [Signed] g.p.m. Date Date June 15., 19.70 Temperature of water Was a chemical analysis made? ☐ Yes 🙀 No (Drilling Machine Operator) (10) CONSTRUCTION: Drilling Machine Operator's License No. ...277 Well seal-Material used ... Bentonite Depth of seal 30 / Water Well Contractor's Certification: Diameter of well bore to bottom of seal \_\_\_\_\_\_16\_\_\_\_\_in. This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Were any loose strata cemented off? 

Yes 
No Depth ..... NAME John Truman Miller
(Person, firm or corporation) (Type or print) Was a drive shoe used? ☐ Yes ☐ No Did any strata contain unusable water? 🔲 Yes 📮 No Address P.O. Box 342 Hubbard, Oregon 97032 Type of water? depth of strata Method of sealing strata off

Contractor's License No. 26 Date June 15 , 19.70

Was well gravel packed? 🗌 Yes 🙀 No Size of gravel: .....

Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_ ft.