

RECEIVED
MAY 6 1966

2 - South Bound CLAC
CLAC
008779
35 C
State Well No. 3/10-26 F

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE OF OREGON (Please type or print)

State Permit No.

(1) OWNER:

Name ORE. STATE HIGHWAY DEPT
Address WILSONVILLE REST AREA

(2) LOCATION OF WELL: WELL NO. 2

County CLACK, Driller's well number 4130
SE 1/4 NW 1/4 Section 26 T. 35 R. 1W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [X] Rotary [] Driven []
Irrigation [] Test Well [] Other [] Cable [X] Jetted []
Dug [] Bored []

(5) TYPE OF WELL:

(6) CASING INSTALLED:

Threaded [] Welded [X]
6" Diam. from 0 ft. to 148 ft. Gage 250
" Diam. from " ft. to " ft. Gage
" Diam. from " ft. to " ft. Gage

(7) PERFORATIONS:

Perforated? [X] Yes [] No
Type of perforator used STAR
Size of perforations 3/8 in. by 1 1/4 in.
200 perforations from 132 ft. to 140 ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No
Manufacturer's Name
Type Model No.
Slot size Set from " ft. to " ft.
Diam. Slot size Set from " ft. to " ft.

(9) CONSTRUCTION:

Well seal—Material used in seal BENTONITE
Depth of seal 20 ft. Was a packer used? No
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? [] Yes [X] No Depth
Was a drive shoe used? [X] Yes [] No
Was well gravel packed? [] Yes [X] No Size of gravel:
Gravel placed from " ft. to " ft.
Did any strata contain unusable water? [] Yes [X] No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 58 ft. below land surface Date 6/1/66
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [X] Yes [] No If yes, by whom? STRASSER
Yield: 42 gal./min. with 8.5 ft. drawdown after 4 hrs.
" " " " "
" " " " "
Bailer test gal./min. with " ft. drawdown after " hrs.
Artesian flow g.p.m. Date
Temperature of water 53° Was a chemical analysis made? [] Yes [X] No

(12) WELL LOG:

Diameter of well below casing
Depth drilled 148 ft. Depth of completed well 148 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	2
YELLOW CLAY	2	18
SANDY CLAY	18	48
BROWN SAND	48	122
SAND CLAY	122	128
SAND AND GRAVEL	128	142
BLUE CLAY	142	149

Work started MAY 19 1966 Completed JUNE 3 1966
Date well drilling machine moved off of well JUNE 3 1966

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME R.J. STRASSER DRILLING Co
(Person, firm or corporation) (Type or print)
Address 8110 SE SUNSET LAKE PORTLAND ORE.
Drilling Machine Operator's License No. 190
[Signed] Robert J. Strasser
(Water Well Contractor)
Contractor's License No. 10 Date JUNE 7 1966