

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310, 1968
within 30 days from the date of well completion.

(Please type or print)
(Do not write above this line)

STATE ENGINEER
SALEM OREGON

CLACK
008782
G-6086
G-4374

State Well No. 3/1w-35

State Permit No.

(1) OWNER:

Name MR EDGAR WOOD
Address AURORA OREGON

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
10" Diam. from 0 ft. to 215 ft. Gage 279
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No
Type of perforator used STAR
Size of perforations 3/8 in. by 1 1/4 in.
240 perforations from 138 ft. to 146 ft.
280 perforations from 168 ft. to 178 ft.
300 perforations from 197 ft. to 208 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 74 ft. below land surface Date 4/1/68
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? STRASSER
Yield: 520 gal./min. with 36 ft. drawdown after 6 hrs.
400 " " 29 " " 1 "
310 " " 23 " " 1 "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 52° Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used CEMENT AND BENTONITE
Depth of seal 30 FT ft.
Diameter of well bore to bottom of seal 14 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County CLACK Driller's well number 4271
SE 1/4 SE 1/4 Section 35 T. 35 R. 1W W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing
Depth drilled 215 ft. Depth of completed well 215 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
TOP SOIL	0	15	
SAND	15	43	
CLAY AND GRAVEL	43	52	
BLUE CLAY	52	74	
BROWN SANDY CLAY	74	95	
GREY CLAY	95	108	
YELLOW CLAY	108	117	
CEMENTED GRAVEL	117	138	
SAND AND GRAVEL	138	146	
BLUE CLAY	146	157	
BLACK SAND	157	163	
SAND AND GRAVEL	163	178	
BLUE CLAY	178	196	
SAND AND GRAVEL	196	208	
BLUE SHALE	208	215	

Work started FEB 26 1968 Completed APR 9 1968
Date well drilling machine moved off of well APR 9 1968

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Carl Baker Date APR 30 1968
(Drilling Machine Operator)

Drilling Machine Operator's License No. 190

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. STRASSER DRILLING CO
(Person, firm or corporation) (Type or print)

Address 8110 SE SUNSET LANE PORTLAND ORE

[Signed] Robert L. Strasser
(Water Well Contractor)

Contractor's License No. 10 Date APR 23 1968