

NOTICE TO WATER WELL CONTRACTOR
 The original and first copy of this report
 are to be filed with the
 WATER RESOURCES DEPARTMENT,
 SALEM, OREGON 97310
 within 30 days from the date
 of well completion.

RECEIVED
 WATER WELL REPORT
 STATE OF OREGON
 NOV 15 1978 (Print)
 WATER RESOURCES DEPT.
 SALEM, OREGON

CLAC
 008997
 State Well No. 351E-6CC
 State Permit No. _____

(1) OWNER:

Name Lake Grove Garden Center
 Address 15955 S.W. Boones Ferry Rd
Lake Grove, Oregon 97034

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
 6" Diam. from +1' ft. to 74' ft. Gage 250
 " Diam. from " ft. to " ft. Gage
 " Diam. from " ft. to " ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.
 Type of perforator used _____
 Size of perforations in. by in.
 perforations from " ft. to " ft.
 perforations from " ft. to " ft.
 perforations from " ft. to " ft.

(7) SCREENS:

Well screen installed? Yes No
 Manufacturer's Name _____
 Type _____ Model No. _____
 Diam. Slot size Set from " ft. to " ft.
 Diam. Slot size Set from " ft. to " ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 gal./min. with " ft. drawdown after " hrs.
 " " " " " "
 " " " " " "
 Bailor test 70 gal./min. with 15 ft. drawdown after 2 hrs.
 Artesian flow g.p.m.
 Temperature of water 52° Depth artesian flow encountered " ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
 Well sealed from land surface to 74' ft.
 Diameter of well bore to bottom of seal 10" to 19' in 8" to 74'
 Diameter of well bore below seal 6" in.
 Number of sacks of cement used in well seal 11 sacks
 How was cement grout placed? Mixed and placed around pipe
 Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
 Did any strata contain unusable water? Yes No
 Type of water? _____ depth of strata _____
 Method of sealing strata off _____
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from " ft. to " ft.

(10) LOCATION OF WELL:

County CLACKAMAS Driller's well number _____
 SW 1/4 SW 1/4 Section 6 T. 35 R. 1E W.M.
 Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 210 ft.
 Static level 110 ft. below land surface. Date _____
 Artesian pressure lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 6"
 Depth drilled 260 ft. Depth of completed well 260 ft.
 Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Soil	0	3	
Light Brown Clay	3	24	
Grey Soft Rock	24	41	
Brown Lava rock	41	72	
Grey Basalt	72	84	
Brown Basalt	84	107	
Grey rock / with layers pumis	107	134	
Brown Basalt	134	181	
Red lava Rock	181	209	
Black Basalt 20 GPM	209	258	110
Ravley round river rock			
will not stay open 70 GPM	258	260	

Work started 8/21 19 78 Completed 8/25 19 78
 Date well drilling machine moved off of well 8/26 19 78

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
 [Signed] Allan J. Harrison Date 8/30, 19 78
 (Drilling Machine Operator)
 Drilling Machine Operator's License No. 842

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
 Name Bello Well Drilling
 (Person, firm or corporation) (Type or print)
 Address 4783 Coloma Dr. S.E. Salem, Ore 97302
 [Signed] Paul Bello
 (Water Well Contractor)
 Contractor's License No. 579 Date 8/30, 19 78