The original and first copy of this report are to be filed with the	CLAC Skate Well No. 3/1-13 &
	FOREGON HUD to ~ /
(1) OWNER:	(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Name DICK LIVERMORE	Was a pump test made? Kyes No If yes, by whom? LIVERMORE
Address RT. 1 Box 562	Yield: 37 gal./min. with 43 ft. drawdown after hrs.
DREGON CITY, OREGON	" 60 " 91 " "
(2) LOCATION OF WELL:	" " "
	Bailer test 23 gal./min. with 15 ft. drawdown after /2 hrs.
County CLACKAMAS Driller's well number 4831	Artesian flow g.p.m. Date
SW 14 SF 14 Section 13 T. 35 R. 1E W.M.	Temperature of water 54 Was a chemical analysis made? Yes No
Bearing and distance from section or subdivision corner	(12) WELL LOG: Diameter of well below casing
	Depth drilled 200 ft. Depth of completed well 200 ft.
	Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.
(3) TYPE OF WORK (check):	MATERIAL FROM TO
and the same of th	Top Soil 0 4
Well Deepening Reconditioning Abandon Landonment, describe material and procedure in Item 12.	KED CLAY 4 12
	BROWN SAMOY CLAY 12 22
(4) PROPOSED USE (check): (5) TYPE OF WELL:	Bive 2 22 44
Domestic Municipal Rotary Driven	BROWN 44 41
Irrigation Test Well Other Dug Bored	Bue 4/60
(A) CLCTVC TYCHLT TYP	620 CAY 90 100
(6) CASING INSTALLED: Threaded Welded	Bus CIAY 100 143
6 "Diam. from 6 ft. to 76 ft. Gage 250"	GREEN CLAY 143 157
ft. toft. Gage	Bug CLAY 157 167
" Diam, from ft. to ft. Gage	CEMENTED GRAVEL 167 175
(7) PERFORATIONS: Perforated? ☐ Yes No	HARD BLACK ROCK 175 200
Type of perforator used	
Size of perforations in. by in.	
perforations from ft. to ft.	
(8) SCREENS: Well screen installed? ☐ Yes ▼ No	
Manufacturer's Name	
Model No.	
Slot size Set from ft. to ft.	Work started 6-18 1966 Completed 6-28 1966
Diam Slot size Set from ft. to ft.	Work started 6 - 18 19 CC Completed 6 - 28 19 CC Date well drilling machine moved off of well 6 - 78 19 CC
(9) CONSTRUCTION:	(13) PUMP:
Well seal—Material used in seal Ben'rewite	Manufacturer's Name
Depth of seal ft. Was a packer used? No	Type: H.P.
Diameter of well bore to bottom of seal	
Were any loose strata cemented off? Yes No Depth	Water Well Contractor's Certification:
Was a drive shoe used? ✓ Yes ☐ No Was well gravel packed? ☐ Yes ☒ No Size of gravel:	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Gravel placed from	NAME RISTRASSER DRILLING GO
Did any strata contain unusable water? Yes No	Address 8110 SE SUNSET LANE SORTLAND ORE
Type of water? , depth of strata	Address 8110 DE SUNSETLANE SORTLAND ORE
Method of sealing strata off	Drilling Machine Operator's License No
(10) WATER LEVELS:	[Signed] . Kobert L. Strasser
Static level 68' ft. below land surface Date 6-28-46	(Water Well Contractor)
Artesian pressure lbs, per square inch Date	Contractor's License No. Date JULY 11, 1966