

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the

STATE ENGINEER, SALEM, OREGON 97301  
within 30 days from the date  
of well completion.

CLAC  
009316

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

RECEIVED  
JUL - 1 1970  
STATE ENGINEER

State Well No. 3/1-16bd  
State Permit No.

(1) OWNER:

Name BILL KAISER  
Address RT 1 Box 367-I  
WEST LINN, OREGON

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

CASING INSTALLED:

Threaded  Welded   
10" Diam. from 0 ft. to 540 ft. Gage .250"  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated?  Yes  No.

Type of perforator used

Size of perforations in. by in.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(7) SCREENS:

Well screen installed?  Yes  No

Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom?  
Yield: gal./min. with ft. drawdown after hrs.  
" " " " " "  
" " " " " "  
Bailer test 45 gal./min. with 70 ft. drawdown after 1 hrs.  
Artesian flow g.p.m.  
Temperature of water 56° Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used BENTONITE  
Well sealed from land surface to 30 ft.  
Diameter of well bore to bottom of seal 13 in.  
Diameter of well bore below seal 10 in.  
Number of sacks of cement used in well seal 0 sacks  
Number of sacks of bentonite used in well seal 2 sacks  
Brand name of bentonite NATIONAL  
Number of pounds of bentonite per 100 gallons of water 200 lbs./100 gals.  
Was a drive shoe used?  Yes  No Plugs Size: location ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County CLACKAMAS Driller's well number 108  
SE 1/4 NW 1/4 Section 16 T. 3S R. 1E W.M.  
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 57 ft.  
Static level 62 ft. below land surface. Date  
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 10" AND 8"  
Depth drilled 725 ft. Depth of completed well ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOP SOIL	0	1	
BROWN CLAY	1	16	
SANDY BROWN CLAY	16	20	
BROWN CLAY	20	36	
BROWN CLAY SOME GRAVEL	36	44	
BROWN CLAY	44	57	
BROWN CLAY AND GRAVEL	57	65	30
SOFT BROWN SANDSTONE	65	80	
BLUE CLAY	80	93	
BROWN CLAY	93	104	
BLUE CLAY	104	310	
BROWN CLAY	310	320	
BLUE CLAY	320	508	
BROWN CLAY	508	540	
DECOMPOSED BASALT	540	544	62
SOFT BROWN BASALT	544	560	62
MED HARD BROWN BASALT	560	585	62
BASALT	585	668	62
HARD BASALT	668		

Work started 3-6 1970 Completed 5-18 1970  
Date well drilling machine moved off of well 5-18 1970

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] CE Keller Date 6-29, 1970  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 329

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name KELLER WELL DRILLING Co.  
(Person, firm or corporation) (Type or print)

Address 5365 S.E. HILLWOOD MILWAUKIE

[Signed] CE Keller  
(Water Well Contractor)

Contractor's License No. 462 Date 6-29, 1970