

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

CLAC
943

WATER WELL REPORT

RECEIVED

STATE OF OREGON JUN 12 1974 State Well No. 15/4E-27

STATE ENGINEER, SALEM, OREGON 97310 (Please type or print) STATE ENGINEER SALEM, OREGON
within 30 days from the date of well completion. (Do not write above this line) State Permit No.

00943

(1) OWNER:

Name ROBERT Loomis
Address 9500 S.E. 352 AVE
BORING, DRE 60V

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
 Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 78 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.
Type of perforator used MILLS KNIFE
Size of perforations 4x in. by 3 in.
60 perforations from 60 ft. to 75 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 30 gal./min. with 27 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 51 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used CEMENT
Well sealed from land surface to 5.5 ft.
Diameter of well bore to bottom of seal 8 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 2 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water SLURRY lbs./100 gals.
of water BACK FILLED WITH CLAY
Was a drive shoe used? Yes No Plus Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County CLACKAMA Driller's well number
1/4 1/4 Section 27 T. 15 R. 4E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 67 ft.
Static level 18 ft. below land surface. Date 6-1-74
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6
Depth drilled 125 ft. Depth of completed well 125 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOP SOIL	0	2	
DENSE RED CLAY	2	21	
YELLOW CLAY	21	36	
CEMENT GRAVEL AND Boulders	36	67	18
WATER BEARING GRAVELS	67	77	
CEMENT GRAVEL AND Boulders	77	125	

Work started 5-9 1974 Completed 6-8 1974
Date well drilling machine moved off of well 6-8 1974

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Perry Doane Date 6-8, 1974
(Drilling Machine Operator)
Drilling Machine Operator's License No. 215

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name PERRY DOANE
(Person, firm or corporation) (Type or print)
Address 1860 S.E. SAMPLE RD CLACKAMAS
[Signed] Perry Doane
(Water Well Contractor)
Contractor's License No. 568 Date 6-8, 1974