

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report are filed with the

**RECEIVED**  
MAR 18 1969

**WATER WELL REPORT**

STATE OF OREGON

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date of well completion

(Please type or print)  
Do not write above this line

**RECEIVED**  
APR 4 1969  
STATE ENGINEER  
SALEM, OREGON

CLAC  
019485

State Well No. 3/1-21 dd

State Permit No.

**(1) OWNER:**

Name Harold Mickelson  
Address Rte 3 Canby, Oregon

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Driven   
Cable  Jetted   
Dug  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**CASING INSTALLED:**

Threaded  Welded   
10" Diam. from 0 ft. to 115 ft. Gage 1/4"  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

**PERFORATIONS:**

Perforated?  Yes  No.

Type of perforator used Millknife  
Size of perforations 3/8 in. by 3/4 in.  
40 perforations from 92 ft. to 93'6" ft.  
40 perforations from 96'6" ft. to 98 ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

**(7) SCREENS:**

Well screen installed?  Yes  No

Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

**(8) WATER LEVEL: Completed well.**

Static level 80 ft. below land surface Date 3/10/69  
Artesian pressure lbs. per square inch Date

**(9) WELL TESTS:**

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom? driller  
Yield: 180 gal./min. with 80 ft. drawdown after 10 hrs.  
" " " "  
" " " "  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water Was a chemical analysis made?  Yes  No

**(10) CONSTRUCTION:**

Well seal—Material used Puddled mud  
Depth of seal 25 ft.  
Diameter of well bore to bottom of seal 16 in.  
Were any loose strata cemented off?  Yes  No Depth  
Was a drive shoe used?  Yes  No  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.

**(11) LOCATION OF WELL:**

County Clackamas Driller's well number  
1/4 1/4 Section 21 T. 3S R. 1E W.M.  
Bearing and distance from section or subdivision corner

**(12) WELL LOG:**

Diameter of well below casing 10

Depth drilled 125 ft. Depth of completed well 125 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Brown top soil	0	2	
Brown clay	2	29	
Brown dry sand	29	80	
Brown clay	80	81	
Brown sand	81	90	
Brown sand & gravel	90	95	
Brown clay	95	96	
Brown sand & gravel	96	99	
Brown Clay	99	101	
Black sand	101	107	
Blue clay	107	117	
Black sand	117	125	

Work started February 13 1969 Completed March 10 1969

Date well drilling machine moved off of well March 10 1969

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] William D. Christensen Date March 10, 1969  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 500

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME John Truman Miller  
(Person, firm or corporation) (Type or print)

Address P.O. Box 342 Hubbard, Oregon

[Signed] John T. Miller  
(Water Well Contractor)

Contractor's License No. 277 Date March 10, 1969