NOTICE TO WATER WELL CONTRACTOR The original and first copy	I DEDODA	
of this report are to be filed with the	L REPORT	35/1E-2266
CI A STATE OF	OREGON. I 1074	- American de la company de la
within 30 days from the date	or phil JUNI7 1974 ove this line) E ENGINEER Permit No	* *************************************
of well completion.	ST TE ENGINEER	
(1) OWNER:	(10) ECCATION OF WELL:	
Thu HERR	County CLACK Driller's well number 5478	
Name PHUL HEBD Address PD Box 524	NW 14 NW 14 Section // T. 25 R. 2E W.M.	
LAKE DEWEGO DEE	Bearing and distance from section or subdivision corner	
(2) TYPE OF WORK (check):	Bearing and distance from section of sabdivision corner	
New Well		**. ***
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 148 ft.	
	Static level 90 ft. below land surface. Date 5/23/74	
Rotary Driven Domestic M Industrial Municipal Dug Bored Irrigation Test Well Other		
Dug Bored I Irrigation Test Well Other I	Artesian pressure lbs. per square inch. Date	
CASING INSTALLED: Threaded □ Welded	(12) WELL LOG: Diameter of well be	elow casing /O
10" Diam. from	Depth drilled 22/ ft. Depth of completed well 22/ ft.	
ft. Gage	Formation: Describe color, texture, grain size and structure of materials;	
ft. to ft. Gage	and show thickness and nature of each stratum and aquifer penetrated,	
PERFORATIONS: Perforated? Yes No.	with at least one entry for each change of formati position of Static Water Level and indicate princ	
PERFORATIONS: Perforated? Yes No.	MATERIAL	From To SWL
Size of perforations in. by in.	TOP SOLL	0 /
perforations fromft. toft.	BROWN CLAY	15
perforations fromft. toft.	CLAY AND BROKEN KOCK	5 /3
perforations fromft. toft.	BROWN SAND	13 19
	DECOMPOSED ROCK	19 26
(7) SCREENS: Well screen installed? Yes No	GREY SILT AND BROKEN KOCK	26 30
Manufacturer's Name	- SILT SAND AND GRAVEL	30 56
Type Model No. Diam. Slot size Set from ft. to ft.	RED BYSALT	81 88
Diam, Slot size Set from ft. to ft.	BINCK BASALT	88 137
	MED HARD GREY BASALT	137 148
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	BROKEN BLACK BASALT	148 179
Was a pump test made? Yes \(\subseteq \text{No If yes, by whom?} \) \(\subseteq \text{RASSER} \)	POROUS BLACK BASALT	179 182
Yield: 306 gal./min. with 54 ft. drawdown after 24 hrs.	MED HARD BROWN BASACT	182 196
n n	MED HARD BLACK BASALT	196 209
" " "	MED. HARD GREY BASALT	209 218
Bailer test gal./min. with ft. drawdown after hrs.	BLOKEN GREY BASALT	720 721
Artesian flow g.p.m.	MED HARD GREY BASAUT	220 221
perature of water 55 Depth artesian flow encounteredft.	Work started APR 25 1974 Complete	1 MAY24 1974
	Date well drilling machine moved off of well	· 100 6 1974
(9) CONSTRUCTION: Well seel Meterial used (EMENT (7800))		00275
Well Seal-Material useu	Drilling Machine Operator's Certification: This well was constructed under my	direct supervision.
Well sealed from land surface toft.	Materials used and information reported	above are true to my
Diameter of well bore to bottom of sealin. Diameter of well bore below sealin.	best knowledge and belief.	
Number of sacks of cement used in well seal sacks	[Signed] Date 6/12, 1974	
Number of sacks of bentonite used in well sealsacks	Drilling Machine Operator's License No.	
Brand name of bentonite		
Number of pounds of bentonite per 100 gallons	Water Well Contractor's Certification:	
of water lbs./100 gals.	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.	
Was a drive shoe used? Yes No Plugs Size: location ft.	Name RISTRASSER DRILLING CO	
Did any strata contain unusable water? Yes No	(Person, firm or corporation) —(Type or print)	
Type of water? depth of strata	Address 8110 SE SUNSET LANE PORTLAND ORE,	
Method of sealing strata off	[Signed] Kaber J. Shang	
Was well gravel packed? Yes No Size of gravel:	(Water Well Contra	
Gravel placed fromft. toft.	Contractor's License No Date	UNE 12, 1974
(USE ADDITIONAL SE	IEETS IF NECESSARY)	SD#45658_110