

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

RECEIVED
JUL 23 1965
WATER WELL REPORT
STATE OF OREGON
(Type or print)
SALEM OREGON

CLAC
009847

State Well No. 3/1-26 E(2)
State Permit No. _____

G-3689

(1) OWNER:

Name DAVE SAMBUCETO
Address 9104 S.E. 41st
Milwaukie, Oregon

(2) LOCATION OF WELL:

County Clackamas Driller's well number 216
SW $\frac{1}{4}$ NW $\frac{1}{4}$ Section 26 T. 3S R. 1E W.M.
Bearing and distance from section or subdivision corner
Tax lot #36
145' South
100' West
Haines Rd.

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
8 " Diam. from 0 ft. to 220 ft. Gage .250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used _____
Size of perforations in. by in.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Model No. _____
Slot size _____ ft. to _____ ft.
Diam. Slot size _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal benonite
Depth of seal 35 ft. Was a packer used? no
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 67 ft. below land surface Date 4/23/65
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Smith
Yield: 50 gal./min. with 13 ft. drawdown after 2 hrs.
" 100 " " 93 " " 4 "
" 130 " " 100 " " 24 "
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow g.p.m. Date _____
Temperature of water 56° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 8"

Depth drilled 222 ft. Depth of completed well 222 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil	0	4
yellow clay	4	30
blue clay	30	78
red sandy clay	78	126
sand (water)	126	130
blue clay	130	170
yellow sandy clay	170	196
weathered basalt (water)	196	220
black basalt	220	222

Work started 3/24 1965 Completed 4/27 1965
Date well drilling machine moved off of well 4/13 1965

(13) PUMP:

Manufacturer's Name DEMING (160' setting)
Type: Turbine (airline 168') H.P. 7 $\frac{1}{2}$

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME AMERICAN WELL DRILLING COMPANY
(Person, firm or corporation) (Type or print)
Address 143 S.E. 95th Ave.

Drilling Machine Operator's License No. 175
[Signed] W.C. Smith
(Water Well Contractor)
Contractor's License No. 375 Date May 5, 1965