NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

CLAGTER WELL REPORT
NOV 1 4 1973 tate Well No. 35 / E-27
STATE OF OREGON STATE ENGINEER

(Please type or print) STATE ENGINEER
State Permit No. .
(Do not write above this line) SALEM, OREGON

(1) OWNER:	(10) LOCATION OF WELL:		
Name WILLAMETTE VALLEY COUNTRY CLUE	County CLACK! Driller's well n	umber 5465	
Address 2396 COUNTRY CLUB ROAD	NW SW 4 Section 27 T. 35	R. / 6 W.M.	
CANBY, ORE	Bearing and distance from section or subdivisi		
(2) TYPE OF WORK (check):			
New Well Deepening Reconditioning Abandon		- 100 m	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed w	-all	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	1		
Rotary Cl Driven Cl	Depth at which water was first found		
Cable V Jetted Domestic Industrial Municipal	Static level 48 ft. below land	surface. Date /0/27/7	
Dug Bored Irrigation Test Well Other	Artesian pressure lbs. per square	re inch. Date	
CASING INSTALLED: Threaded Welded			
12" Diam from 0 ft to 150 ft Gage 330	(12) WELL LOG: Diameter of well	below casing	
8 " Diam from 128 ft. to 300 ft. Gage . 277	Depth drilled 300 ft. Depth of completed well 300 ft.		
" Diam. fromft. toft. Gage	Formation: Describe color, texture, grain size	and structure of materials;	
Jamin 1011 and 11 Wage	and show thickness and nature of each stratu- with at least one entry for each change of forma	m and aquifer penetrated,	
PERFORATIONS: Perforated? X Yes No.	position of Static Water Level and indicate prin	cipal water-bearing strata.	
Type of perforator used TORCH	MATERIAL	From To SWL	
Size of perforations 3/32 in. by 6 in.	TOP SOIL		
992 perforations from 150 ft. to 295 ft.	BROWN CLAY	2 4	
	BOULDERS AND GLAY	4 24	
perforations fromft. toft.	CLAY AND GRAVEL		
perforations from ft. to ft.	BOULDERS AND CLAY	24 50	
(7) SCREENS: Well screen installed? Yes No	CLAY AND GRAVEL	50 54	
Manufacturer's Name	GREY CLAY	59 15	
Type Model No.	BLUE SANDY CLAY	45	
Diam. Slot size Set from ft. to ft.	GREY CLAY	110 118	
Diam	STICK BLUE CLAY	118 135	
(0)	GREY SANDY CLAY	135 160	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	HARD BLACK SAND	160 175	
Was a pump test made? Yes No If yes, by whom?	BROWN SANDY CLAY	175 184	
Yield: 240 gal./min. with 76 ft. drawdown after 8 hrs.	BLUE AND GREY GLAY	184 215	
Board and A	BROWN SANDY CLAY	215 230	
" " " "	BLUE CLAY	230 245	
	BLACK SANDY CLAY	245 284	
Bailer test gal./min. with ft. drawdown after hrs.	GREY MUDSTONE	284 300	
Artesian flow g.p.m.		307 23 23	
perature of water SSDepth artesian flow encounteredft.	Work started Sept /7 19 7.3 Complete	ed DOT 30 1973	
(0) CONSTRUCTION.	Date well drilling machine moved off of well	4/ / /	
(9) CONSTRUCTION: Well seel Metarial used CEMENT GROUT		NOU, 1, 1973	
Seal-Matterial useu	Drilling Machine Operator's Certification:	7.	
Well sealed from land surface toft.	This well was constructed under my direct supervision. Materials used and information reported above are true to my		
Diameter of well bore to bottom of seal in.	[Signed] (Drilling Machine Operator) Date Nov 9, 1973		
Diameter of well bore below seal			
Number of sacks of cement used in well seal sacks	Drilling Machine Operator's License No		
Number of sacks of bentonite used in well seal sacks	Diming Machine Operator's Incense No		
Brand name of bentonite	Water Well Contractor's Certification:	•	
Number of pounds of bentonite per 100 gallons	This well was drilled under my jurisdi	ction and this wannet :-	
of water lbs./190 gals.	true to the best of my knowledge and beli	ef.	
Was a drive shoe used? Yes No Plugs Size: location ft.	Name K.J. STRAISSER DE	ILLING 6	
Did any strata contain unusable water? 🗌 Yes 🕱 No	(Person, firm or corporation)	Type or print)	
Type of water? depth of strata	Address 8/10 SE DUNSET LANG	FORTLAND ORE	
Method of sealing strata off	V[Signed] Cabout I	assor	
Was well gravel packed? Yes No Size of gravel:	(Water Well Contra	ictor)	
Gravel placed from 150 ft. to 300 ft.	Contractor's License No Date	NOU 9 1073	
(USE ADDITIONAL SH		27.1.2	