

RECEIVED

STATE OF OREGON AUG 12 1986 WATER WELL REPORT WATER RESOURCES DEPT (as required by ORS 537.785)

CLAC 009700

35/E-282a

(1) OWNER: Lee Rhoads, 2797 N Locust, Canby, OR 97013

(9) LOCATION OF WELL by legal description: County Clac., Township 3 So., Range 1 E, Section 28, NE 1/4, SE 1/4, Street Address of Well (or nearest address) 2797 N. Locust Canby, Oregon 97013

(2) TYPE OF WORK: [X] New Well, [] Deepen, [] Recondition, [] Abandon

(10) STATIC WATER LEVEL: 101' ft. below land surface, Date 7-19-86, Artesian pressure _____ lb. per square inch. Date _____

(3) DRILL METHOD: [X] Rotary Air, [] Rotary Mud, [] Cable, [] Other

(11) WELL LOG: Ground elevation _____

(4) PROPOSED USE: [] Domestic, [] Community, [] Industrial, [X] Irrigation, [] Thermal, [] Injection, [] Other

Table with 5 columns: Material, From, To, WB?, SWL. Rows include Top Soil, Clay-Brown, Clay-Blue, Sand-Clay-Brown, Gravel Comp., Clay-Blue, Gravel Comp., Sand-Black Fine, Clay-Bule, Sandstone Bl. Frat., Clay-Blue, Sand-Black Fine, Clay-Blue, Sand Blue Fine, Clay-Blue, Clay-Sand Blue-Blk/Fr.

(5) BORE HOLE CONSTRUCTION: Depth of Completed Well 430 ft., Special Standards date of approval _____

Table with 6 columns: HOLE Diameter, From, To, SEAL Material, From, To, Amount sacks or pounds. Row: 12" diameter, 0' to 19' cement seal, 20 bags.

How was seal placed? Method [] A [] B [X] C [] D [] E, Backfill placed from _____ ft. to _____ ft. Material _____, Gravel placed from _____ ft. to _____ ft. Size of gravel _____

(6) CASING/LINER: Table with 8 columns: Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded. Row: 8" casing, 16" to 350' gauge, .250" steel.

Final location of shoe(s) _____

PERFORATIONS/SCREENS: [X] Perforations Method Air Perf., [] Screens Type _____ Material _____

Table with 7 columns: From, To, Slot size, Number, Diameter, Tele/pipe size, Casing, Liner. Row: 173' to 183' slot size 1/8x1", Number 400, Casing [X], Liner []

Date started 6-14-86 Completed 7-19-86

(8) WELL TESTS: Minimum testing time is 1 hour. [] Pump, [] Bailer, [X] Air, [] Flowing Artesian. Yield gal/min 120, Pumping level _____, Drill stem at 170', Time 3hr.

(unbonded) Water Well Constructor Certification: I constructed this well in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.

Signed _____ Date _____

(bonded) Water Well Constructor Certification: I accept responsibility for construction of this well and its compliance with all Oregon water well standards. This report is true to the best of my knowledge and belief.

Signed George Wainwright Date 8-9-86

Temperature of water 54, Depth Artesian Flow Found _____, Was a water analysis done? [] Yes By whom _____, Did any strata contain water not suitable for intended use? [] Too little, [] Salty [] Muddy [] Odor [] Colored [] Other _____, Depth of strata: _____

Company B & G Drilling Co. Job No. 285