

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED WATER WELL REPORT

STATE OF OREGON (Please type or print)

State Well No. 3/1-28 abc

State Permit No. G-4620

(1) OWNER: STATE ENGINEER

Name Andrus, Gordon
Address 207 NW 3rd
Canby Oregon

(2) LOCATION OF WELL:

County Clackamas Driller's well number 1966-16
1/4 Section 28 T. 35 R. 1E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Rotary Driven
Irrigation Test Well Other Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
8" Diam. from 0 ft. to 184 ft. Gage 2.5
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite
Depth of seal 70 ft. Was a packer used? no
Diameter of well bore to bottom of seal 11 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 90 ft. below land surface Date May 31-66
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Andrus
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
Bailer test 60 gal./min. with 10 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 8
Depth drilled 190 ft. Depth of completed well 184 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil	0	3
Sand Brown medium	3	66
Gravel + sand	66	68
Sand, brown, med	68	72
Gravel + sand	72	74
Gravel, med. to large	74	78
Sand, med. + med gravel	78	101
Sand, Brown, medium	101	105
Sand + gravel, blue med	105	107
Gravel, coarse	107	118
Clay, blue	118	159
Sand, fine	159	162
Clay, Blue	162	184
Sand - med (water)	184	189
Clay - blue	189	190

Work started Feb 18 1966 Completed May 31 1966
Date well drilling machine moved off of well May 31 1966

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Skyles Drilling & Supply
(Person, firm or corporation) (Type or print)

Address Gladstone, Oregon

Drilling Machine Operator's License No. 222-224

[Signed] George D. Skyles
(Water Well Contractor)

Contractor's License No. 58 Date May 31, 1966