

CLAC

(1) OWNER:

Name Tom & John R. Dodds
Address 799 N.E. Columbia Blvd.
Portland 11, Oregon

(2) LOCATION OF WELL:

County Clackamas Owner's number, if any—
NE 1/4 SW 1/4 Section 28 T.3 S. R.1 E. W.M.
Bearing and distance from section or subdivision corner

Well is located S. 0 deg. 2' W. 3535.11 ft.
and N. 89 deg. 18' W. 1012.11 ft. from the
North quarter section corner of Section
28; T.3 S. R.1 E. of W.M. in Clackamas
County, Oregon

TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

10 " Diam. from Top ft. to _____ ft. Threaded Welded
_____ " Diam. from _____ ft. to _____ ft. Gage 31.20#
_____ " Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used Mills
SIZE of perforations 3/8 in. by 1 1/2 in.
72 perforations from 65 ft. to 72 ft.
128 perforations from 95 ft. to 117 ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? 20 ft.
Material used in seal— Fuddled clay
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 58 ft. below land surface Date 8-23-57
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by: John Dodds
[Signed] _____ Date Aug 26, 1957
(Owner)

(11) WELL TESTS:

Drawdown Emil O. Beier level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: 600 gal./min. with 14 ft. drawdown after 4 hrs.
" 400 " " 7 " " 4 "
" 300 " " 5 " " 4 "

Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 56 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 10 inches.

Depth drilled 175 ft. Depth of completed well 158 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil	0	5
Sandy loam	5	18
Dry gravel & boulders	18	65
Loose gravel (Water)	65	70
Boulders	70	73
Hard Blue clay	73	95
Tight Gravel	95	112
Gravel (Some Water)	112	118
Blue Clay	118	155
Gray & Black Sand some Wood (WATER)	155	160
Blue Clay	160	175

Work started 7-30-57 19 _____ Completed 8-23-57 19 _____

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Emil O. Beier
(Person, firm, or corporation) (Type or print)

Address 7555 O'Neil Road Salem, Oregon

Driller's well number 367

[Signed] Emil O. Beier
(Well Driller)

License No. 89 Date 8-23-57, 19 _____