

CLACK 09760

WATER WELL REPORT  
STATE OF OREGON

State Well No. 3/1-28R (1)

State Permit No. G1142

(1) OWNER:

Name Kenneth M. Christensen  
Address Route 3 Box 556B  
Canby, Oregon

RECEIVED  
NOV 20 1957  
STATE ENGINEER  
SALEM, OREGON

(2) LOCATION OF WELL:

County Clackamas Owner's number, if any—  
?—SE 1/4 SE 1/4 Section 28 T. 3S R. 1E W.M.  
Bearing and distance from section or subdivision corner  
The West one acre of the East 1/4 acres of tract 59--Canby Gardens

TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
When abandoned, describe material and procedure in Item 11.

PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED:

Threaded  Welded   
6" Diam. from 0 ft. to 68 ft. Gage .250  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used \_\_\_\_\_  
SIZE of perforations in. by in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

SCREENS:

Well screen installed  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

CONSTRUCTION:

Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Was a surface seal provided?  Yes  No To what depth? \_\_\_\_\_ ft.  
Material used in seal—  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

(10) WATER LEVELS:

Static level 48 ft. below land surface Date 10/14/57  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

Log Accepted by:

[Signed] K.M. Christensen Date \_\_\_\_\_, 19\_\_\_\_  
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
" " " " " "  
" " " " " "  
" " " " " "  
Bailer test 30 gal./min. with no ft. drawdown after 2 hrs.  
Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
Temperature of water \_\_\_\_\_ Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well \_\_\_\_\_ 6 \_\_\_\_\_ inches.  
Depth drilled 72 ft. Depth of completed well 72 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Top soil	MATERIAL	FROM	TO
Top soil		0	3
Loosley cemented gravel and boulders		3	52
Loose gravel and boulders		52	57
Cement gravel		57	62
Loose gravel		62	68
Cement gravel		68	69
Brown clay		69	72
Gravel		72	

Work started October 19 57 Completed October 19 57

(13) PUMP:

Manufacturer's Name \_\_\_\_\_  
Type: \_\_\_\_\_ H.P. \_\_\_\_\_

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Steinman Bros.  
(Person, firm, or corporation) (Type or print)

Address 15112 S.E. McLoughlin Blvd. Milwaukie Ore.

Driller's well number 37-57

[Signed] Bob McConnell  
(Well Driller)

License No. 1 Date October 15, 1957