

RECEIVED
AUG 31 1959

CLAC

5/2-1R1

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

STATE ENGINEER WATER WELL REPORT 009836

SALEM, OREGON

STATE OF OREGON

State Well No. _____ State Permit No. _____

(1) OWNER:

Fischer

Name Delbert Fischer
Address Rt 2 Box 372
Mololla Oregon

(2) LOCATION OF WELL:

County Clackamas Owner's number, if any—
S.E. 1/4 S.E. 1/4 Section 1 T. 55. R. 2E. W.M.
Bearing and distance from section or subdivision corner
From The S.E. Corner of Sec. 1-1/2 E. 1/4 S.E. 1/4, go west 600 FT then N. 4500 FT

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 107 1/2 ft. Gage 17 lb.
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used _____
SIZE of perforations in. by in.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name _____ Type _____ Model No. _____
_____ Slot size _____ Set from _____ ft. to _____ ft.
_____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel: _____ ft.
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? 25 ft.
Material used in seal— Concrete and casing
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 20 ft. below land surface Date Aug 28
Artesian pressure _____ lbs. per square inch Date _____
Log Accepted by: _____
[Signed] Delbert Fischer, 19_____,
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? _____

Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
" " " " "
" " " " "
" " " " "
Bailer test 20 gal./min. with 50 ft. drawdown after 2 hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 6 inches.
Depth drilled 137 ft. Depth of completed well 122 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Brown soil	0	5
Co. glomerate gravel & sand	5	25
Hard blue clay	25	120
Black sand (water)	120	

Work started Aug 11 1959 Completed Aug 27 1959

(13) PUMP:

Manufacturer's Name _____ Type: _____ H.P. _____

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Richard P. Tolleson
(Person, firm, or corporation) (Type or print)
Address Rt. 1 Box 268 Mulino Oregon
Driller's well number 8-59
[Signed] Richard P. Tolleson
(Well Driller)
License No. 268 Date Aug 29, 19_____,