STATE	ENGINEER			
Salem, Oregon				

Well Record Columbia STATE WELL NO. 5N/2W-25A COUNTY Columbia APPLICATION NO. GR-4272

OWNER: Fred Luttrell	MAILING	Poute 1 F	80× 658	
•	CITY AND			
LOCATION OF WELL: Owner's No.		St. Helens,	Oregon	
NE 1/4 NE 1/4 Sec. 25 T. 5 S, R. 2 W.,	w.M.	,	A	
Bearing and distance from section or subdivision				
corner 1200 feet SW of corner of Section be	tween 25 and			
.30				
***************************************	and the second terms are the second			
Altitude at well 260 feet				
TYPE OF WELL: Drilled Date ConstructedJu				
Depth drilled 685 feet Depth cased 685 fee	<u>t</u>	Section	25	. 5
10-inch casing set from 0 to 141 feet open hole 141 to 685 feet				
FINISH:				
rinisii.				
AQUIFERS:				
sand and clay				
WATER LEVEL:				
231 feet				
PUMPING EQUIPMENT: Type Peerless			нР	
Capacity .250 G.P.M.			***************************************	
WELL TESTS:				
Drawdown179 ft. after	hours	250	ک جو النامیات استان استان او جو به پرونو	G.P.M.
Drawdown ft. after	hours			G.P.M.
USE OF WATER Irrigation SOURCE OF INFORMATION GR-4123 DRILLER or DIGGER self		°F		
ADDITIONAL DATA:				
LogX Water Level Measurements	Chemical Aı	nalysis	Aquifer Test	
REMARKS:				
clay 0 to 141 basalt rock 141 to 211				
blue sandstone 211 to 580				
heavy granular sand (water) 580 to 685				