NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

C014
1438
NC

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

RECEIVED
DEC 11 1974
STATE ENGINEER
SALEM, OREGON

State Well No. 5N/3W-1

State Permit No.

(1) OWNER:

Name BOB ADAMS

Address R72-219 Deer island

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒

6 in" Diam. from 0 ft. to 30 ft. Gage 250

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☐ Yes ☒ No.

Type of perforator used

Size of perforations in. by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

" " " "

Bailer test 20 gal./min. with 4 ft. drawdown after 1 hrs.

Artesian flow g.p.m.

Temperature of water 48 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used CEMENT

Well sealed from land surface to 20 ft.

Diameter of well bore to bottom of seal 10 in.

Diameter of well bore below seal 6 in.

Number of sacks of cement used in well seal 5 sacks

Number of sacks of bentonite used in well seal sacks

Brand name of bentonite

Number of pounds of bentonite per 100 gallons of water lbs./100 gals.

Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Colum B14 Driller's well number

¼ ¼ Section 1 T. 5 R. 3 W W.M.

Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 170 ft.

Static level 145 ft. below land surface. Date 9/10

Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6 in

Depth drilled 178 ft. Depth of completed well 178 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
SOIL BLACK	0	2	0
CLAY BROWN WITH			
SMALL BOULDERS	2	10	0
CLAY BLUE	10	25	0
SANDSTONE BLUE	25	68	0
SANDSTONE GRAY	68	178	145

Work started 8/23 1974 Completed 9/10 1974

Date well drilling machine moved off of well 9/11 1974

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] G.A. Luttrell (Drilling Machine Operator) Date 10/12, 1974

Drilling Machine Operator's License No. 198

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name G.A. LUTTRELL WELL DRILLING (Person, firm or corporation) (Type or print)

Address Rt. 1 Box 732 St. Helens

[Signed] G.A. Luttrell (Water Well Contractor)

Contractor's License No. 238 Date 10/12, 1974

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-11