NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

COLLU 2020

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED FEB 14 1973 STATE ENGINEER SALEM, OREGON

State Well No. 7N/2W-26 ba
State Permit No. G-6015

(1) OWNER:
Name Charlie Kelley
Address Rt #2 Box 75 Rainier, Oregon

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☒
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒
8" Diam. from +2 ft. to 45 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☐ Yes ☒ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " "
" " "
AIR
Bailer test 75 gal./min. with 106 ft. drawdown after 1½ hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Cement
Well sealed from land surface to 30 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 11 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Columbia Driller's well number
¼ ¼ Section 26 T. 7 R. 2W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 189 ft.
Static level 94 ft. below land surface. Date 1-15-73
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 8"
Depth drilled 200 ft. Depth of completed well 200 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Yellow clay	0	8	
Yellow Clay & Gravel	8	22	
Blue Clay	22	28	
Rock, Blue solid	28	33	
Rock, Broken	33	45	
Rock, Black, "Hard"	45	189	
Rock, Fractured, Water			94
Bearing	189	191	
Rock, Black Hard	191	200	

Work started 1-7- 1973 Completed 1-15 1973
Date well drilling machine moved off of well 1-16 1973

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Walter Williams (Drilling Machine Operator) Date 2-11, 1973
Drilling Machine Operator's License No. 427

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Williams Well Drilling Co (Person, firm or corporation) (Type or print)
Address Rt #1 Box 128 Toledo, Wash.
[Signed] W. T. Williams (Water Well Contractor)
Contractor's License No. 455 Date 2-10, 1973

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119