NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

RECEIVED
OCT 11 1968
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

CCOLW
2266

Test Well No. 3
State Well No. 7N/3W-13
State Permit No.

(1) OWNER:
Name Briarcliff Properties
Address Box D, Rainier, Oregon

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☑ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☑ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☑
6" Diam. from 0 ft. to 92 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? ☐ Yes ☑ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.
Static level 60 ft. below land surface Date 4-18-68
Artesian pressure lbs. per square inch Date

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " "
" " " "
Bailer test 30 gal./min. with 130 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☑ Yes ☐ No

(10) CONSTRUCTION:
Well seal—Material used cement grout
Depth of seal 30 ft.
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? ☐ Yes ☑ No Depth
Was a drive shoe used? ☑ Yes ☐ No
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:
County Columbia Driller's well number
¼ ¼ Section 13 T. 7 R. 3 W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG: Diameter of well below casing 6
Depth drilled 136 ft. Depth of completed well 136 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
soil, brown sandy	0	2	
Clay, yellow	2	30	
Red, clay	30	40	
Brown, clay	40	70	
Black, basalt	70	95	
Gray, basalt, water bear-	95	136	

Work started 4-8 1968 Completed 4-18 1968
Date well drilling machine moved off of well 4-19 1968

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Farrel McGhee Date 4-30, 1968
(Drilling Machine Operator)
Drilling Machine Operator's License No. 362

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Farrel Mc Ghee Well Drilling
(Person, firm or corporation) (Type or print)
Address 1020 Industrial Way Longview.
[Signed] Farrel McGhee
(Water Well Contractor)
Contractor's License No. 438 Date 4-30, 1968

(USE ADDITIONAL SHEETS IF NECESSARY)