NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

COLU 2621

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED JUN - 6 1977 WATER RESOURCES DEPT. SALEM, OREGON

State Well No. 8N/3W-34
State Permit No.

(1) OWNER:
Name Richard Washburn
Address Rt.1 Box 290 Rainier, Oregon

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED: Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 107 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? ☒ Yes ☐ No.
Type of perforator used Mills Knife
Size of perforations 10 in. by $\frac{1}{4}$x$1\frac{1}{2}$ in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
d: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 14 gal./min. with 50 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
perature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Bentonite & Cement
Well sealed from land surface to 30 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 2 sacks
Number of sacks of bentonite used in well seal 2 sacks
Brand name of bentonite Western
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Columbia Driller's well number
¼ ¼ Section 34 T. 8N R. 3W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 95 ft.
Static level 50 ft. below land surface. Date 5-5-77
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing
Depth drilled 107 ft. Depth of completed well 107 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Clay, grey	0	46	
Clay, brown	46	50	
Shale, red	50	85	
Shale, grey, water bearing	85	95	
Shale, grey, light	95	107	

Work started 4-30 19 77 Completed 5-5 19 77
Date well drilling machine moved off of well 5-5 19 77

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Farrel McGhee Date 5-10, 19 77
(Drilling Machine Operator)
Drilling Machine Operator's License No. 362

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Farrel McGhee Well Drilling
(Person, firm or corporation) (Type or print)
Address 1020 Industrial Way Longview, Wn.
[Signed] Farrel McGhee
(Water Well Contractor)
Contractor's License No. 438 Date 5-10, 19 77

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119

COLU 2621

Hackleman, Richard



SW/SW - 34 c, cgl