

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the

# WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

State Well No. 3N1W-7

State Permit No. 2993

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date  
of well completion.

**(1) OWNER:**

Name RUDD'S TRAILER COURT  
Address RT 2 BOX 316 B #9B  
SCAPPOOSE, OREGON

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Driven   
Cable  Jetted   
Dug  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**CASING INSTALLED:**

Threaded  Welded   
" Diam. from +1 ft. to 62 ft. Gage .250"

**PERFORATIONS:**

Perforated?  Yes  No.

Type of perforator used

Size of perforations in. by in.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

**(7) SCREENS:**

Well screen installed?  Yes  No

Manufacturer's Name JOHNSON  
Type Model No.  
Diam. 5" Slot size 14 Set from 67 ft. to 72 ft.  
Diam. 5" Slot size 20 Set from 62 ft. to 67 ft.

**(8) WELL TESTS:**

Drawdown is amount water level is  
lowered below static level

Was a pump test made?  Yes  No If yes, by whom?  
Yield: gal./min. with ft. drawdown after hrs.  
" " " " " "  
" " " " " "  
Bailer test 50 gal./min. with 33 ft. drawdown after 1 hrs.  
Artesian flow g.p.m.

**(9) CONSTRUCTION:**

Well seal—Material used CEMENT  
Well sealed from land surface to 31 ft.  
Diameter of well bore to bottom of seal 6 1/2 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal 38 sacks  
Number of sacks of bentonite used in well seal 0 sacks  
Brand name of bentonite  
Number of pounds of bentonite per 100 gallons  
of water lbs./100 gals.  
Was a drive shoe used?  Yes  No Plugs Size: location ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.

**(10) LOCATION OF WELL:**

County COLUMBIA Driller's well number 374  
1/4 1/4 Section 7 T. 3N R. 1W W.M.  
Bearing and distance from section or subdivision corner

**(11) WATER LEVEL: Completed well.**

Depth at which water was first found 18 ft.  
Static level 8 ft. below land surface. Date 12/14/76  
Artesian pressure lbs. per square inch. Date

**(12) WELL LOG:**

Diameter of well below casing

Depth drilled 75 ft. Depth of completed well 72 ft.

Formation: Describe color, texture, grain size and structure of materials;  
and show thickness and nature of each stratum and aquifer penetrated,  
with at least one entry for each change of formation. Report each change in  
position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOP SOIL	0	1	
BROWN CLAY	1	4	
CEMENTED GRAVEL	4	19	
BLUE CLAY	19	29	
CEMENTED GRAVEL	29	37	
LOOSE GRAVEL	39	63	
COARSE SAND	63	66	8
(WATER BEARING)			
LOOSE SAND AND			
GRAVEL	66	73	8
(WATER BEARING)			
FINE SAND, SOME			
GRAVEL	73	75	

**RECEIVED**  
DEC 27 1976  
WATER RESOURCES DEPT!  
SALEM, OREGON

Work started 12/7 19 76 Completed 12/14 19 76  
Date well drilling machine moved off of well 12/14 19 76

**Drilling Machine Operator's Certification:**  
This well was constructed under my direct supervision.  
Materials used and information reported above are true to my  
best knowledge and belief.  
[Signed] OKeller Date 12/16, 19 76  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 329

**Water Well Contractor's Certification:**  
This well was drilled under my jurisdiction and this report is  
true to the best of my knowledge and belief.  
Name Kenel Well Drilling Co  
(Person, firm or corporation) (Type or print)  
Address 6350 SE BROWNLEE MILWAUKIE  
[Signed] OKeller  
(Water Well Contractor)  
Contractor's License No. 462 Date 12/16, 19 76