ORIGINAL File Original, and DEGETVE WATER WELL DRILL	LERS REPORT Do Not State Well No. 3 1/2V-12Q(1)
File Original, and DEGEIVE WATER WELL DRILL DUPLICATE WITH THE ENGINEER SALEM OREGON OF D 14 1956	EGON Fill In State Permit No.
(1) OWNER: Name Steinfeld Pickle Co.	(10) WELL TESTS: Steinman Bros. Pacific Pumping Co;s Pump
Address P.O.Box 2589 Portland, 3, Oregon.	Was a pump test made? Yes No If yes, by whom? Yield: 300 gal./min. with to 54 ft. draw down after hrs.
Address Tables Coop Lot of Control of Orogons	" 400 to 70 from top "
W	" 495 " 77 " " " "
(2) LOCATION OF WELL:	Artesian flow g.p.m.
Owner's number, if any	Shut-in pressure
R. F. D. or Street No. Scappoose, Oregon.	Bailer test g.p.m. with ft. drawdown
Bearing and distance from section or subdivision corner Well on the south City limits of	Temperature of water Was a chemical analysis made? Yes No
Scappoose, Oregon.	Was electric log made of well? Yes No
485 E 4 884 N from 5'4 corner	(11) WELL LOG:
Section 12 T3N 2W	Diameter of well,
TYPE OF WORK (check):	Total depth 1614 ft. Depth of completed well 164 ft.
New well Deepening Reconditioning Abandon	Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each
bandonment, describe material and procedure in Item 11.	show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.
(4) PROPOSED USE (check): (5) EQUIPMENT:	ft. to ft.
estic 🗆 Industrial 🖈 Municipal 🖂 Rotary	0 " 5 "Gravel fill material
Irrigation ☐ Test Well ☐ Other ☐ Cable Dug Well ☐	5 " 11 "large gravel & boulders
GLOTTO THOUSAND	ll" 16 "cement gravel
CASING INSTALLED: If gravel packed	16" 29 "loose gravel
Threaded	29 " 35 "cement gravel
FROM ft. to ft. Diam. Wall of Bore ft. ft.	35 " 40 loose grey gravel
" 0 "xkáž " 8 " .280" none " "	40" 45 "loose sand & gravel, brown 45" 57 "brown cemented gravel
<u>" "164 " " " " " " " " " " " " " " " " " " "</u>	
1) 1) 1) 1) 1)	57" 59 "cemented gravel 59" 70 "fine brown sand & gravel
11 11 11 11 11 11 11 11 11 11 11 11 11	70 " 80 "cemented gravel
Type and size of shoe or well ring Size of gravel:	80 " 83 "loose gravel, 25 G.P.M.
Describe joint Welded-Steel Shoe	83 " 91 "green sand silt & gravel
	91" 98 "3" cemented with sand, silt
(7) PERFORATIONS:	98 " 101 "loose gravel & sand
Type of perforator used Mills Knife	101 " 132 "cemented gravel.50 G.P.M.
SIZE of perforations 15 in., length, by in. OM ft. to ft, perf per foot No. of rows	132 " 136 "loose gravel
"113 " 155 " 4 " " I foot apart	136 " 148 "cemented gravel.3" minus 148 " 151 "looser gravel
" " " " " " " " " " " " " " " " " " "	148 " 151 "looser gravel 151 " 159 "cemented gravel
n n n n n n	159 " 164 " sand & gravel.
11 11 11 11 11 11 11 11	" "
SCREENS:	n n
Give Manufacturer's Name, Model No. and Size	"
none	" "
(8) CONSTRUCTION:	n n
Was a surface sanitary seal provided? Yes No To what depth ft.	
Were any strata sealed against pollution? ♣ Yes ☐ No If yes, note depth of strata	Ground elevation at well sitefeet above mean sea level. Work started 19 19 56 Completed 20 19 56
FROM O ft. to Abt. 30 ft.	
" with cuttings	Well Driller's Statement: This well was drilled under my jurisdiction and this report is
METHOD OF SEALING filled around pipe	true to the best of my knowledge and belief.
	NAME Steinman Bros.
(9) WATER LEVELS: ***********************************	(Person, firm, or corporation) (Typed or printed)
Resident Static 39 ft.	Address 8332, S.E. 16th. Ave. Portland 2.
RODORKKARRATORRESERVAR SCRUTE SA	Driller's well number / 1556
Log Accepted by:	2) A /LL
	[Signed] (Well Driller)
[Signed] Dated, 19, 19	License No DatedSept. 12, 19.56