

WATER WELL REPORT
STATE OF OREGON

COLU
3169

RECEIVED

OCT 7 1983

State Well No. 3A/2W-19

State Permit No.

PLEASE TYPE or PRINT IN INK
WATER RESOURCES DEPT.
SALEM, OREGON

(1) OWNER:

Name Fred Bonnet
Address 51364 Dike Rd
City Scappoose State ORE

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air Driven
Rotary Mud Dug
 Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other
Thermal: Withdrawal Reinjection

(5) CASING INSTALLED:

Steel Plastic
Threaded Welded
6" Diam. from +2 ft. to 15.3 ft. Gauge 350

LINER INSTALLED:

" Diam. from ft. to ft. Gauge

(6) PERFORATIONS:

Perforated? Yes No

Type of perforator used
Size of perforations in. by in.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Well: gal./min. with ft. drawdown after hrs.
Air test 50 gal./min. with drill stem at 135 ft. 2 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes No

Well seal—Material used Cement + 5 lb Bentonite
Well sealed from land surface to 24 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 10 sacks
How was cement grout placed? pumped
Was pump installed? Type HP Depth ft.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Columbin Driller's well number
1/4 1/4 Section 19 T. 35 R. 2W W.M.
Tax Lot # Lot Blk Subdivision
Address at well location: 50776 Dike Rd

(11) WATER LEVEL: Completed well.

Depth at which water was first found 50 ft.
Static level 27 ft. below land surface. Date 9-29-83
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6

Depth drilled 155 ft. Depth of completed well 155 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Fill	0	10	
BAN CLAY	10	12	
Blue clay	12	67	
BROWN/BLACK CLAY	67	96	
FINE BLUE SAND	96	118	
COARSE BLUE SAND + GRAVEL	118	155	

Work started 9-28 19 83 Completed 9-29 19 83
Date well drilling machine moved off of well 9-29 19 83

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Date, 19.....

Bonded Water Well Constructor Certification:

Bond 140898 Issued by: ORE Auto Ins Co
(number) Surety Company Name

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name TURNER DRILLING Co
(Person, firm or corporation) (Type or print)

Address 14825 N.W. Gilligan Rd Pent.
10 on Fecker

[Signed]
Water Well Constructor
Date 10-5, 19 83

NOTICE TO WATER WELL CONSTRUCTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

SP*45292-690