

RECEIVED

COLU

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON (Please type or print)

SALEM, OREGON

3228

State Well No. 3N 12W-24 State Permit No.

(1) OWNER:

Name ROY W. SAXTON Address Rt. 1 Box 170 Scappoose, ORE.

(2) LOCATION OF WELL:

County Columbia Driller's well number 1/4 Section 24 T. 3 N.R. 2 W.M. Bearing and distance from section or subdivision corner 330 ft N.E. Corner 20 ft South from Northline.

(3) TYPE OF WORK (check):

New Well X Deepening Reconditioning Abandon abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic X Industrial Municipal Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Cable Dug Driven Jetted Bored

(6) CASING INSTALLED:

6" Diam. from 0 ft. to 89 ft. Gage 1/4 Threaded Welded

(7) PERFORATIONS:

Perforated? Yes No Type of perforator used Size of perforations in. by in. perforations from ft. to ft.

(8) SCREENS:

Well screen installed Yes No Manufacturer's Name Model No. diam. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal NYROUT Depth of seal 18 ft. Was a packer used? NO Diameter of well bore to bottom of seal 8 in. Were any loose strata cemented off? Yes No Depth Was a drive shoe used? Yes No Was well gravel packed? Yes No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? Yes No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 3.5 ft. below land surface Date 5/11 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? Yes No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Bailer test 45 gal./min. with 15 ft. drawdown after 3 hrs. Artesian flow g.p.m., Date Temperature of water 52 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing Depth drilled ft. Depth of completed well ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows: Soil Brown (0-2), Clay Yellow Fine (2-6), Sand Blue (6-31), Gravel medium (31-55), Sand Gray Water Bearing (55-82), Gravel Small (82-89)

Work started 5/3 1963 Completed 5/11 1963 Date well drilling machine moved off of well 5/11 1963

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME G.A. Luttrell Well Drilling (Person, firm or corporation) (Type or print)

Address St. Helens Pl. 1 Box 732

Drilling Machine Operator's License No. 198

[Signed] G.A. Luttrell (Water Well Contractor)

Contractor's License No. 238 Date 5/17 1963