

MAY 18 2001

STATE OF OREGON WATER SUPPLY WELL REPORT (as required by ORS 537.765)

WELL I.D. # L 48786 START CARD # 122672

Instructions for completing this report are on the last page of this form.

(1) OWNER: City of Scappoose Well Number PO BOX P Scappoose OR 97050

(2) TYPE OF WORK: Alteration (repair/recondition)

(3) DRILL METHOD: Cable

(4) PROPOSED USE: Community

(5) BORE HOLE CONSTRUCTION: Depth of Completed Well 225 ft.

Table with columns: Diameter, From, To, Material, From, To, Sacks or pounds. Entry: 12" 0 227 - FROM EXISTING LOG INFO.

How was seal placed: Method C. *METHOD C' USED TO PLACE CEMENT PLUG

Table for (6) CASING/LINER with columns: Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded.

Table for (7) PERFORATIONS/SCREENS with columns: From, To, Slot size, Number, Diameter, Tele/pipe size, Casing, Liner.

(8) WELL TESTS: Minimum testing time is 1 hour. Pump yield 600 gal/min, drawdown 105.

Temperature of water 54.0. Depth Artesian Flow Found. Was a water analysis done? No.

(9) LOCATION OF WELL by legal description: County Columbia, Township 3 N, Range 2 E, Section 13 SW, 1/4 SW. Street Address: 338 Dutch Canyon Rd Scappoose, OR 97050.

(10) STATIC WATER LEVEL: 65 ft. below land surface. Date 11-6-00.

(11) WATER BEARING ZONES: Depth at which water was first found. Table with columns: From, To, Estimated Flow Rate, SWL. Includes handwritten 'N/A'.

(12) WELL LOG: Ground Elevation. Super chlorinated entire column. Well casing and screen scrubbed with wire brush then screen swabbed thoroughly for development. Acid (unicid) injected into screen portion to break-up clog bacteria then all acid pumped out. A cement plug was placed at bottom of screen 3' to reduce influx of sand coming from open bottom well then super chlorinating.

Date started 10-20-00 Completed 10-31-00. (unbonded) Water Well Constructor Certification: I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards.

(bonded) Water Well Constructor Certification: I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. Signed Michael Waldrop, Date April 13, '01.