

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

COOS STATE OF OREGON

(Please type or print)

(Do not write above this line)

RECEIVED

OCT 22 1973

State Well No. 235/13W-35

STATE ENGINEER SALEM, OREGON

State Permit No.

1496

(1) OWNER:

Name 904w w Bundy
Address 7234 Wilbwood Dr
WORTH BEND, OR

(2) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [] Driven []
Cable [x] Jetted []
Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [x] Industrial [] Municipal []
Irrigation [] Test Well [] Other []

(5) CASING INSTALLED:

6" Diam. from 0 ft. to 37 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? [] Yes [x] No

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [] Yes [x] No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [] Yes [x] No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.
Bailer test 15 gal./min. with 25 ft. drawdown after 1 hrs.

Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal-Material used SAOUL CEMENT, Bentonite
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 1 sacks
Number of sacks of bentonite used in well seal 1 sacks
Brand name of bentonite SAOUL
Number of pounds of bentonite per 100 gallons
of water lbs./100 gals.
Was a drive shoe used? [] Yes [x] No Plugs Size: location ft.
Did any strata contain unusable water? [] Yes [x] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [] Yes [x] No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County COOS Driller's well number
1/4 1/4 Section 35 T. 23 R. 13 W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 40 ft.
Static level 2.3 ft. below land surface. Date 9/27/72
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6
Depth drilled 113 ft. Depth of completed well 113 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include: LIGHT BR. CLAY (0-22), BLUE CLAYSTONE (22-88), BLUE SANDSTONE (88-113).

Work started 9/25 19 72 Completed 9/27 19 72
Date well drilling machine moved off of well 9/27 19 72

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Thomas E. Bonnett Date 11-13, 19 72
(Drilling Machine Operator)

Drilling Machine Operator's License No. 756

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name BARRINGTON WELL DRILLING
(Person, firm or corporation) (Type or print)

Address WORTH BEND, OR

[Signed] Dan Barrington
(Water Well Contractor)

Contractor's License No. 201 Date NOV 11, 19 72