STATE OF OREGON

WATER WELL REPORT
(as required by ORS 537.765)

RECEIVED
DEC 19 1985
WATER RESOURCES DEPT
SALEM, OREGON

PLEASE TYPE or PRINT IN INK

COOS 209

27s/13W-33dd

(for official use only)

(1) OWNER:
Name: Josephus Clafton Eason
Address: Rt. 1, Box 3964
City: Coquille State: Ore

(2) TYPE OF WORK (check):
New Well ☐ Deepening ☒ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary Air ☐ Driven ☐
Rotary Mud ☐ Dug ☐
Cable ☒ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Thermal: Withdrawal ☐ Reinjection ☐
Other: Piezometric ☐ Grounding ☐ Test ☐

(5) CASING INSTALLED:
Steel Threaded ☒ Plastic Welded ☒
6" Diam. from +1 ft. to 49 ft. Gauge .250
" Diam. from ft. to ft. Gauge

LINER INSTALLED:
Steel Threaded ☐ Plastic Welded ☒
5" Diam. from 40 ft. to 170 ft. Gauge .214

(6) PERFORATIONS:
Perforated? ☐ Yes ☐ No
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☐ No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " "
Air test gal./min. with drill stem at ft. hrs.
Bailer test 40 GPH gal./min. with 70 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 52 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Special standards: Yes ☐ No ☒
Well seal—Material used Bentonite with 3% Bentonite Cement
Well sealed from land surface to 48 ft.
Diameter of well bore to bottom of seal 9 in.
Diameter of well bore below seal 6 in.
Amount of sealing material 9 sacks ☒ pounds ☐
How was cement grout placed? Pumped via tremie pipe

Was pump installed? Yes Type SUB HP 1/2 Depth 165 ft.
Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL by legal description:
County Coos SE ¼ SE ¼ of Section 33 of
Township 27s (Township is North or South), Range 13w (Range is East or West), WM.
Tax Lot 300 Lot Block Subdivision
MAILING ADDRESS OF WELL (or nearest address) SAME

(11) WATER LEVEL of COMPLETED WELL:
Depth at which water was first found 94 ft.
Static level 92 ft. below land surface. Date 12-10-85
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 6
Depth drilled 170 ft. Depth of completed well 170 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Deepening			
Siltstone dark gray	120	146	
Claystone brittle gray	146	152	
Siltstone dark gray	152	170	

Date work started 12-9-85 /completed 12-10-85
Date well drilling machine moved off of well 12-10 19 85

(unbonded) Water Well Constructor Certification (if applicable):
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Date , 19

(bonded) Water Well Constructor Certification:
Bond 28042900 (number) Issued by: Western Surety (Surety Company Name)
On behalf of Bill Miller Well Drilling (type or print name of Water Well Constructor)
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:
(Signed) Andrew W. Miller (Water Well Constructor)
(Dated) 12-17-85

NOTICE TO WATER WELL CONSTRUCTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*46866-690