NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

State Well No	z65/12W-15
State Permit No.	***************************************

(Do not write above this line)

(1) OWNER:	(10) LOCATION OF WELL:			
Name John H.Schilling	County Coos Driller's well number S/23/U			
Address Box 363 South Coos River	34 34 Section 15 T. 26S R. 12W W.M.			
Goos Bay, Oregon 97420	Bearing and distance from section or subdivision corner			
(2) TYPE OF WORK (check):		ion come		
New Well 🙀 Deepening 🗌 Reconditioning 🗍 Abandon 🗍				
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL Completed m			
(3) TYPE OF WELL: (4) PROPOSED USE (check):	- (11) WATER LEVEL: Completed well. Depth at which water was first found 80 ft.			
Rotary K Driven Domestic Industrial Municipal Domestic			Data M	, ,
Cable			1-1	11/79
	Artesian pressure lbs. per squa	re inch.	Date	
CASING INSTALLED: 6 "Diam. from 0 ft. to 50 ft. Gage .250 4"PVisianliner 0 ft. to 225 ft. Gage 160# "Diam. from ft. to ft. Gage	(12) WELL LOG: Diameter of well below casing6			
PERFORATIONS: Perforated? K Yes No.	position of Static Water Level and indicate prin	1	1	
Type of perforations 4 round holles in.	MATERIAL Tongo 1	From	To	SWL
	Topsoil	0 1	5	
perforations from ft. to 160	Brown clay Yellow clay	5	12	
100	Gray claystone	12	24	
100perforations from185	Blue sandstone	24	48	
(7) SCREENS: Well screen installed? Yes ** No	Gray sandstone	48	130	
Manufacturer's Name	Cong Sandstone	130	148	
Type	Gray sandstone	148	225	
Diam Slot size Set from ft. to ft.				
Diam Slot size Set from ft. to ft.				
(8) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? Yes X No If yes, by whom?	RECEIVED			
Yield: gal./min. with ft. drawdown after hrs.	AUG 91070			
" " "	בוטוש ביטו			
" - 1 - "-1 - 1 - 1 - 1 - 1	WATER RESOURCES DEPT.			
Tested with air: could "fluctuate "	SALEM, OREGON			
Batter test 2 gal./min. with 205t. drawdown after 4 hrs.				
Artesian flow g.p.m.				
perature of water Depth artesian flow encountered ft.	Work started 7/10/79 19 Complet	ed 7/1	1/79	19
(9) CONSTRUCTION:	Date well drilling machine moved off of well	7/11	/79	19
Well seal—Material used	Drilling Machine Operator's Certification:			
Well sealed from land surface toft.	This well was constructed under my Materials used and information reported	direct		vision.
Diameter of well bore to bottom of sealin.	best knowledge and belief			· ·
Diameter of well bore below seal6in.	[Signed]	Date ?/	16/79	19
Number of sacks of cement used in well seal Sacks	(Drilling Machine Operator)			
How was cement grout placed?	Drilling Machine Operator's License No.	02	9	***************************************
Pumped through tremie	Water Well Contractor's Certification:			
	This well was drilled under my jurisdiction and this report is			
Was a drive shoe used? D Yes S No Plugs Size: location ft.	true to the best of my knowledge and belief. Name Corvallis Drilling Co. Inc.			
Did any strata contain unusable water? Yes No	(Person, firm or corporation) (Type or print)			
Type of water? depth of strata	Address 3440 SW 3rd St. Corvallis, Oregon 97330			
Method of sealing strata off	[Signed] Lik Sa	_		
Was well gravel packed? ☐ Yes X No Size of gravel:	(Water Well Contractor)			
Gravel placed from ft. to ft.	Contractor's License No. 721 Date 7	/16/79)	, 19
· · · · · · · · · · · · · · · · · · ·				