

RECEIVED

COOS

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

JUL 22 1966

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE ENGINEER SALEM OREGON

STATE OF OREGON (Please type or print)

003752

State Well No. 28/146-4A

State Permit No.

(1) OWNER:

Name Owen H. Barton
Address 980 N Elliott, Coquille Ore

(2) LOCATION OF WELL:

County COOS Driller's well number NE 1/4 NE 1/4 Section 24 T. 28 S R. 14 W.W.M.
Bearing and distance from section or subdivision corner 100' E of 305 of intersection of 101 Highway + Randolph Rd

(3) TYPE OF WORK (check):

New Well [checked] Deepening [] Reconditioning [] Abandon []
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [] Test Well [checked] Other [checked]

(5) TYPE OF WELL:

Rotary [] Driven [] Cable [checked] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

6" Diam. from 0 ft. to 75 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? [] Yes [checked] No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? [checked] Yes [] No
Manufacturer's Name Johnson
Model No. Stainless
Slot size 60 Set from 75 ft. to 80 ft.
Slot size 210 Set from 80 ft. to 91 ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite
Depth of seal 18 ft. Was a packer used? [checked] No
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? [] Yes [checked] No
Was a drive shoe used? [checked] Yes [] No
Was well gravel packed? [] Yes [checked] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? [] Yes [checked] No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 6 ft. below land surface Date 7-14-66
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [checked] Yes [] No If yes, by whom?
Yield: 60 gal./min. with 11 ft. drawdown after 5 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 53 Was a chemical analysis made? [] Yes [] No

(12) WELL LOG:

Diameter of well below casing 0
Depth drilled 92 ft. Depth of completed well 91 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Entries include: Bulldozed area, Sand, Bog mud, Sand (Brown), Peat + Wood, Tan fine sand, Red sand, Gray sand, Tan sand, Blue river silt.

Water right will be filed soon.

Work started 7-6-66 Completed 7-11-66
Date well drilling machine moved off of well 7-11-66

(13) PUMP:

Manufacturer's Name None
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME George R Miller
Address Rt Box 561 Bandon
Drilling Machine Operator's License No. 33
[Signed] George R Miller
Contractor's License No. 372 Date 7-14-66