

STATE OF OREGON
WATER WELL REPORT
 (as required by ORS 537.765)

COOS
 COOS 3899

RECEIVED

NOV 21 1985

28-14W-28

PLEASE TYPE or PRINT IN INK

WATER RESOURCES DEPT
SALEM, OREGON

(for official use only)

(1) OWNER:

Name *Ramond Gardner*
 Address *Rt 2 Box 346*
 City *Bandon* State *OR*

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air Driven
 Rotary Mud Dug
 Cased Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Thermal:
 Irrigation Withdrawal ReInjection
 Other:
 Piezometric Grounding Test

(5) CASING INSTALLED:

Steel Plastic
 Threaded Welded
4 1/2 Diam. from *7.2* ft. to ~~11.2~~ *38* Gauge *SPP 26*
 " Diam. from ft. to ft. Gauge

LINER INSTALLED:

Steel Plastic
 Threaded Welded
 " Diam. from ft. to ft. Gauge

(6) PERFORATIONS:

Perforated? Yes No
 Size of perforations in. by in.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
 Manufacturer's Name *Hydrophilic*
 Type *P.O.C* Model No. *plastic*
 Diam. *4 1/2* Slot Size *1.0* Set from *38* ft. to *92* ft.
 Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 d: gal./min. with ft. drawdown after hrs.
 Air test *24* gal./min. with drill stem at *92* ft. *1* hrs.
 Bailer test gal./min. with ft. drawdown after hrs.
 Artesian flow g.p.m.
 Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes No
 Well seal—Material used *Grout cement*
 Well sealed from land surface to *20* ft.
 Diameter of well bore to bottom of seal *9* in.
 Diameter of well bore below seal *4 1/2* in.
 Amount of sealing material *9 3/4* sacks pounds
 How was cement grout placed? *Tremie pipe pumped*

 Was pump installed? *NO* Type HP Depth ft.
 Was a drive shoe used? Yes No Plugs Size: location ft.
 Did any strata contain unusable water? Yes No
 Type of Water? depth of strata
 Method of sealing strata off
 Was well gravel packed? Yes No Size of gravel:
 Gravel placed from ft. to ft.

(10) LOCATION OF WELL by legal description:

County *COOS* 1/4 1/4 of Section *28* of
 Township *28* Range *14* WM.
 (Township is North or South) (Range is East or West)
 Tax Lot Lot Block Subdivision
 MAILING ADDRESS OF WELL (or nearest address) *chow lane*

(11) WATER LEVEL of COMPLETED WELL:

Depth at which water was first found *8* ft.
 Static level *18* ft. below land surface. Date *10-15*
 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing *4 1/2*
 Depth drilled *102* ft. Depth of completed well *92* ft.
 Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
<i>sandy Brown clay</i>	0	7	
<i>lt Brown sand & clay</i>	7	52	
<i>Blue sand w/wood & ch</i>	52	102	

Date work started *10-14* / completed *10-15*
 Date well drilling machine moved off of well *10-15* 19 *85*

(unbonded) Water Well Constructor Certification (if applicable):
 This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Date, 19

(bonded) Water Well Constructor Certification:

Bond Issued by:
 (number) (Surety Company Name)
 On behalf of *Barrington Well Drilling*
 (type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

(Signed) *Tom Barrington*
 (Water Well Constructor)

(Dated) *10-23-85*

NOTICE TO WATER WELL CONSTRUCTOR
 The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
 SALEM, OREGON 97310
 within 30 days from the date of well completion.

SP*46866-690