

RECEIVED

COOS
003901

285/14W-28C2

STATE OF OREGON
WATER WELL REPORT
(as required by ORS 537.765)

APR 30 1985

WATER RESOURCES DEPT

PLEASE TYPE or PRINT IN INK

(for official use only)

(1) OWNER:
Name Louis Pallin
Address Route 2, Box 307 D
City Bandon State Ore.

(2) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: (4) PROPOSED USE (check):
Rotary Air Driven Domestic Industrial Municipal
Rotary Mud Dug Irrigation Thermal: Withdrawal ReInjection
Other: Piezometric Grounding Test
Cable Bored

(5) CASING INSTALLED: Steel Plastic
6" Diam. from * 1 ft. to 97'-5" ft. Gauge .250
Threaded Welded

LINER INSTALLED: NO
Steel Plastic
Threaded Welded

(6) PERFORATIONS: Perforated? Yes No
Size of perforations in. by in.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(7) SCREENS: Well screen installed? Yes No
Manufacturer's Name Johnson
Type Stainless steel Model No. telescope
Diam. 6 Slot Size .008 Set from 96'-5" ft. to 107'-5" ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
..... gal./min. with ft. drawdown after hrs.
Air test gal./min. with drill stem at ft. hrs.
Bailer test 20 gal./min. with 8 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 52 Depth artesian flow encountered ft.

(9) CONSTRUCTION: Special standards: Yes No
Well seal—Material used Cement
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Amount of sealing material 15 sacks pounds
How was cement grout placed? Pumped via tremie pipe

Was pump installed? Yes Type Sub HP 2 Depth 105 ft.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL by legal description:
County Coos NE 1/4 SW 1/4 of Section 28 of
Township 28s Range 14w WM.
(Township is North or South) (Range is East or West)
Tax Lot 1600 Lot Block Subdivision
MAILING ADDRESS OF WELL (or nearest address) Same

(11) WATER LEVEL of COMPLETED WELL:
Depth at which water was first found 58 ft.
Static level 58 ft. below land surface. Date 4-25-85
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 0
Depth drilled 108 ft. Depth of completed well 107'-5" ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Sand fine tan	0	4	
Clay brown	4	6	
Cemented sand brown	6	8	
Sand medium brown	8	15	
Sand with clay white	15	35	
Clay gray	35	39	
Sand very fine tan tight	39	50	
Sand medium tan tight	50	56	
Sand medium-coarse gray	56	67	58
Peat clay with wood black	67	73	
Clay gray	73	74	
Gravel and sand blue tight	74	84	58
Sand medium-fine blue-gray	84	87	
Sand medium gray	87	96	
Sand coarse gray	96	104	
Sand medium gray	104	108	

Date work started 4-22-85 /completed 4-25-85
Date well drilling machine moved off of well 4-25 19 85

(unbonded) Water Well Constructor Certification (if applicable):
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Date, 19

(bonded) Water Well Constructor Certification:
Bond 28042900 Issued by: Western Surety
(number) (Surety Company Name)
On behalf of Bill Miller Well Drilling Lic.# 600
(type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:
(Signed) Andrew Miller
(Dated) April 28 1985
(Water Well Constructor)

NOTICE TO WATER WELL CONSTRUCTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

SP*46866-690