

RECEIVED

OCT 27 1965

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

STATE ENGINEER
STATE OF OREGON
SALEM OREGON (Please type or print)

COOS

003921

State Well No. 28/14w-28 G

State Permit No.

(1) OWNER:

Name John Conrad
Address R1 Box 72 Bandon OR

(2) LOCATION OF WELL:

County COOS Driller's well number
SW 1/4 NE 1/4 Section 28 T. 28 S. R. 14 W. M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
In abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 110.8 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No

Manufacturer's Name Johnson
Type Telescope Model No.
6" Slot size 008 Set from 110 ft. to 115 ft.
8" Slot size 010 Set from 110 ft. to 120 ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite
Depth of seal 18 ft. Was a packer used? No
Diameter of well bore to bottom of seal 9 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 79 ft. below land surface Date 10-21-65
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: 37 gal./min. with 21 ft. drawdown after 72 hrs.
" " " " "
" " " " "
" " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing Filed

Depth drilled 130 ft. Depth of completed well 120 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Sandy top soil	0	1
Packed Brownsand	1	78
gray "	7	19
Red cement sand	18	19
Fine Brownsand	19	30
White sandy clay	30	46
Fine gray sand	46	75
gray silt	75	85
Coarse gray sand	85	121
gray sand with clay & wood		
Placed gravel to 120	120	130
set screen on some		

Work started 10-16 1965 Completed 10-21 1965
Date well drilling machine moved off of well 10-21 1965

(13) PUMP:

Manufacturer's Name Berkley
Type Sub 10 stage H.P. 1 1/2

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME George A Miller
(Person, firm or corporation) (Type or print)

Address R1 Box 561 Bandon

Drilling Machine Operator's License No. 33

[Signed] George A Miller
(Water Well Contractor)

Contractor's License No. 77 Date 10-25, 1965