

**NOTICE TO WATER WELL CONTRACTOR**

The original and first copy of this report are to be filed with the

**RECEIVED** WATER WELL REPORT 0003

JUL 3 1970 STATE OF OREGON

STATE ENGINEER, SALEM, OREGON 97310

(Please type or print)

within 30 days from the date of well completion.

STATE ENGINEER SALEM, OREGON

State Well No. 29/15W-126a

004352

State Permit No.

**(1) OWNER:**

Name Frank Makolandra  
Address General Delivery Bandan Ore

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Driven   
Cable  Jetted   
Dug  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**(5) CASING INSTALLED:**

Threaded  Welded   
6" Diam. from 0 ft. to 40 ft. Gage 250  
" Diam. from " ft. to " ft. Gage "  
" Diam. from " ft. to " ft. Gage "

**(6) PERFORATIONS:**

Perforated?  Yes  No  
Type of perforator used \_\_\_\_\_  
Size of perforations in. by in.  
perforations from " ft. to " ft.  
perforations from " ft. to " ft.  
perforations from " ft. to " ft.  
perforations from " ft. to " ft.  
perforations from " ft. to " ft.

**(7) SCREENS:**

Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) WATER LEVEL: Completed well.**

Static level 6 ft. below land surface Date 6-27  
Artesian pressure lbs. per square inch Date

**(9) WELL TESTS:**

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: gal./min. with ft. drawdown after hrs.  
" " " " "  
" " " " "  
Bailer test 6 gal./min. with 1 1/2 ft. drawdown after 1 1/2 hrs.  
Artesian flow g.p.m. Date \_\_\_\_\_  
Temperature of water 52 Was a chemical analysis made?  Yes  No

**(10) CONSTRUCTION:**

Well seal—Material used Bentonite & Cement  
Depth of seal 18 ft.  
Diameter of well bore to bottom of seal 10 in.  
Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
Was a drive shoe used?  Yes  No  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(11) LOCATION OF WELL:**

County Cook Driller's well number \_\_\_\_\_  
SE 1/4 SW 1/4 Section 12 T. 29 S. R. 15 W. W.M.  
Bearing and distance from section or subdivision corner  
632' west and 465' north of 1/4 section  
corner between sections 12  
and 13

**(12) WELL LOG:**

Diameter of well below casing 6  
Depth drilled 73 ft. Depth of completed well 73 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top soil brown	0	1	
Clay brown	1	5	
Sand Medium gray	5	11	
Sandy Clay brown	11	13	
Silt & SAND gray	13	33	
Sandy Clay brown	33	35	
Siltstone gray	35	67	
Siltstone with fine gravel	67	73	

Work started 6-27 1970 Completed 6-29 1970  
Date well drilling machine moved off of well 6-29 1970

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Andrew W. Miller Date July 1, 1970  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 469

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
NAME George R. Miller  
(Person, firm or corporation) (Type or print)  
Address Rt 6 Box 561 Bandan Ore  
[Signed] George R. Miller  
(Water Well Contractor)  
Contractor's License No. 322 Date 7-1, 1970