

STATE OF OREGON
WATER WELL REPORT
 (as required by ORS 537.765)

RECEIVED
 MAR 14 1985
 PLEASE TYPE OR PRINT IN INK
WATER RESOURCES DEPT
SALEM, OREGON

COOS

004495

30S/15W-13ab
 (for official use only)

(1) OWNER:

Name Harry Spencer (Growth Unlimited)
 Address P.O. Box 291
 City Langlois State Ore

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air Driven Domestic Industrial Municipal
 Rotary Mud Dug Irrigation Thermal Reinjection
 Cable Bored Other: Piezometric Grounding Test

(4) PROPOSED USE (check):

Withdrawal Rejection Test

(5) CASING INSTALLED:

Steel Threaded Plastic Welded
 6" Diam. from + 1 ft. to 34'-9" ft. Gauge .250

LINER INSTALLED:

NO
 " Diam. from ft. to ft. Gauge

(6) PERFORATIONS:

Perforated? Yes No
 Size of perforations in. by in.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
 Manufacturer's Name Johnson
 Type Stainless steel Model No. telescope
 Diam. 6 Slot Size .008 Set from 33'-11" to 39'-8" ft.
 Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 Yield: gal./min. with ft. drawdown after hrs.
 Air test gal./min. with drill stem at ft. hrs.
 Bailer test 12 gal./min. with 5 ft. drawdown after 1 hrs.
 Artesian flow g.p.m.
 Temperature of water 52 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes No
 Well seal—Material used Cement
 Well sealed from land surface to 21 ft.
 Diameter of well bore to bottom of seal 10 in.
 Diameter of well bore below seal 6 in.
 Amount of sealing material 12 sacks pounds
 How was cement grout placed? Pumped via tremie pipe
 Was pump installed? Yes Type Sub HP 3/4 Depth 39 ft.
 Was a drive shoe used? Yes No Plugs Size: location ft.
 Did any strata contain unusable water? Yes No
 Type of Water? depth of strata
 Method of sealing strata off
 Was well gravel packed? Yes No Size of gravel: ft.
 Gravel placed from ft. to ft.

(10) LOCATION OF WELL by legal description:

County Coos NW $\frac{1}{4}$ NE $\frac{1}{4}$ of Section 13 of
 Township 30s Range 15w WM.
 (Township is North or South) (Range is East or West)
 Tax Lot 102 Lot Block Subdivision
 MAILING ADDRESS OF WELL (or nearest address) 8 Mile south of Bandon on Hiway 101

(11) WATER LEVEL OF COMPLETED WELL:

Depth at which water was first found 25 ft.
 Static level 25 ft. below land surface. Date 2-25-85
 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 0
 Depth drilled 42 ft. Depth of completed well 39'-8" ft.
 Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Location of well SW corner of property.			
Clay and sand fill area	0	3	
Sand with clay brown	3	6	
Sand fine brown	6	24	
Sand fine tan	24	27	
Sand medium gray	27	40	
Claystone blue	40	41	

Date work started 2-25-85 /completed 2-26-85
 Date well drilling machine moved off of well 2-26 19 85

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] _____ Date _____, 19 _____

(bonded) Water Well Constructor Certification:

Bond 28042900 Issued by: Western Surety
 (number) (Surety Company Name)
 On behalf of Bill Miller Well Drilling
 (type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:

(Signed) Bill Miller Lic # 600
 (Water Well Constructor)

(Dated) 3-15-85

NOTICE TO WATER WELL CONSTRUCTOR
 The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
 SALEM, OREGON 97310
 within 30 days from the date of well completion.

SP*46866-690