

RECEIVED

28-14-04

STATE OF OREGON WATER SUPPLY WELL REPORT (as required by ORS 537.765)

MAR 18 2003

WELL I.D. # L 57065 START CARD # 147848

Instructions for completing this report are on the last page of this code book.

(1) LAND OWNER Name: Bandon Dennis Address: 57744 Kowin Lake Dr City: Bandon State: OR Zip: 97411

(2) TYPE OF WORK [X] New Well [] Deepening [] Alteration (repair/recondition) [] Abandonment

(3) DRILL METHOD: [] Rotary Air [X] Rotary Mud [] Cable [] Auger [] Other

(4) PROPOSED USE: [X] Domestic [] Community [] Industrial [] Irrigation [] Thermal [] Injection [] Livestock [] Other

(5) BORE HOLE CONSTRUCTION: Special Construction approval [] Yes [X] No Depth of Completed Well: 60'2" (70')

Table with columns: HOLE Diameter, From, To, Material, SEAL From, To, Sacks or pounds. Row 1: 10", 0, 60, Bentonite, 0, 41, 23 SX

How was seal placed: Method [] A [] B [] C [] D [] E [X] Other: Poured from surface

Backfill placed from 41 ft. to 60 ft. Material: Size of gravel: 10/20

(6) CASING/LINER: Casing: 5" +1 54 1/2" 160# [] Plastic [X] Welded [X] Threaded [] Liner: 6" +1 4' 1250 [X] (Protective casing)

(7) PERFORATIONS/SCREENS: Table with columns: From, To, Slot size, Number, Diameter, Tele/pipe size, Casing, Liner. Row 1: 54 1/2", 60'2", .014", 1, 5", Pipe

(8) WELL TESTS: Minimum testing time is 1 hour. [] Pump [] Bailer [X] Air [] Artesian. Yield gal/min: 20 Drawdown: - Drill stem at: 60 Time: 1 hr.

Temperature of water: 52° Depth Artesian Flow Found: Was a water analysis done? [X] Yes By whom: BWT-S Did any strata contain water not suitable for intended use? [] Too little [] Salty [] Muddy [] Odor [] Colored [] Other

Depth of strata: Bandon Well & Septic Co., Inc.

(9) LOCATION OF WELL by legal description: County: Coos Latitude: Longitude: Township: 28 N or S Range: 14 E or W. WM. Section: 04 SW 1/4 NW 1/4 Tax Lot: 1300 Lot: Block: Subdivision: Street Address of Well (or nearest address): 57404 Serendipity Rd, Bandon

(10) STATIC WATER LEVEL: 27'3" ft. below land surface. Date: 3/14/03 Artesian pressure: lb. per square inch Date:

(11) WATER BEARING ZONES: Table with columns: From, To, Estimated Flow Rate, SWL. Row 1: 27'3, 58, +/-20, 27'3

(12) WELL LOG: Ground Elevation: +/-300' Table with columns: Material, From, To, SWL. Rows include: Sandy clay brown (0-2), Sand Fine-med brown (2-13), Sand Fine-med w/sandy (13-15), Clay tan, Sand Fine-med tan w/ (15-45), Gravel Fine med brown, Sand Fine w/gravel fine (45-47), +sandy clay brown, Sand Fine-med w/gravel (47-49), Fine green black, Clay orange (49-50), Gravel Fine-med w/sand (50-58), Fine-cls gray black, Sandy clay gray (58-60)

Date started: 3/13/03 Completed: 3/14/03

(unbonded) Water Well Constructor Certification: I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Signed: Chris Reaney WWC Number: 1759 Date: 3/17/03

(bonded) Water Well Constructor Certification: I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. Signed: Jim MacLennan WWC Number: 1493 Date: 3/17/03